

BUILDING SAFETY CERTIFICATE

No.

Dated:

Certified that the existing building Kendriya Vidyalaya, Kurnool (name of the building or premises) at Near Nandyal Check post, B-comp post, Kurnool, (A.P.) (address) comprised of 01 basement(s) and 01 (upper floors) owned/occupied by Kendriya Vidyalaya, Kurnool (name of the Institution) have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of Principal, KV, Kurnool (Name of Department/ Govt.) on 11/07/2024 (date of inspection) in the presence of Principal, KV, Kurnool (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy upto classes XII (X/ XII) with effect from 11/07/2024 for a period of ONE (01) years in accordance with rule and subject to compliance of the specific conditions as appended.

1. The K.V school building of G.F is uneven levels
2. due to settlement of flooring
3. The KV school Hf compound wall is tilt some places
4. Many places leakages in the building appeared

Issued on 11/07/2024 at KURNOOL by J. PRUTHVI RAJ
AE, KURNOOL

* Strike out whichever is not applicable.

Signature with Seal :

G.S.S. Srinivas / जी. एस. एस. श्रीनिवास

Executive Engineer/कार्यपालक अभियंता

Name : Kurnool Central Division/ कुर्नूल केंद्रीय मंडल

Designation : Central P.W.D./ केन्द्रीय लोक निर्माण विभाग

Name & Address of Department/ Office: Kurnool-518007/ कुर्नूल -518007

(Assistant Engineer & above officer of concerned Govt. Department only)

Note: This certificate should be signed / issued by Assistant Engineer & above officer of concerned Govt. Department only

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.