

# Annexure D

## BUILDING SAFETY CERTIFICATE

No. 23(33)/EV/KNL/EE/Kurnool/2026/460 (H) Dated: 4/8/2026

It is certified that the existing building Kendriya vidyalaya kurnool (name of the building or premises) at Near nandyal chue post, B. Camp, post kurnool, A.P. (address) is having block(s)/Floor(s) as per details below:

| Detail of Block(s) in school | Block (1) | Block (2)      | Block (3) | Block (4) | Block (5) | Block (6) |
|------------------------------|-----------|----------------|-----------|-----------|-----------|-----------|
| No. of Floor(s) in the Block | 2         | GF + 1st floor |           |           |           |           |

The building is owned/occupied by Kendriya vidyalaya, kurnool (name of the Institution) have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of EE, CPWD, kurnool (Name of Department/ Govt.) on ..... (date of inspection) in the presence of principal, kv, kurnool (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy for running school with effect from 4/8/2026 for a period of ..... years in accordance with rule and subject to compliance of the specific conditions as appended.

1. Kv School Compound was damaged, dilapidated Condition
  2. First floor toilet slab concrete fully damaged needs structural repairs
  3. All the drainage system is not operative, no effective septictank
  4. needs ~~urgent~~ urgent construction, windows are not operative needs replacement, M.C. steel
- Issued on 04/8/2026 at 01:00 pm by

\* Strike out whichever is not applicable. In case of block is more than six use separate sheet for detail.

Signature with Seal: A. Sreenivasa Rao  
Name: A. Sreenivasa Rao  
Designation: EE, civil

Name & Address of Department/ Office:

A. Sreenivasa Rao/ए. श्रीनिवास राव  
Executive Engineer/ कार्यकारी अभियंता  
Kurnool Central Division/ कर्नूल केंद्रीय विभाग  
Central P.W.D./ केंद्रीय सार्वजनिक निर्माण विभाग  
Kurnool-518008/ कर्नूल-518008