

GOVERNMENT OF ANDHRA PRADESH
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT

From :
The Director General,
State Disaster Response and Fire Services,
Andhra Pradesh, Vijayawada.

To :
The District Educational Officer,
Eluru, West Godavari District.

Rc.No. 2379/MSB/ER/WG/2021, Dt:31.07.2021

Sir,

Sub: A.P. State Disaster Response and Fire Services Department- MSB Section -
Issuance of No Objection Certificate for Occupancy to Existing Building of
M/s. Kendriya Vidyalaya, Gopannapalem, West Godavari District -
Regarding.

- Ref:**
1. Application of M/s. Kendriya Vidyalaya, Gopannapalem, West Godavari District.
 2. This Office Memo Rc.No.2379/WG/HRB/ER/2021, Dt: 12-07-2021.
 3. Inspection Committee Report Rc.No. 972/DFO/WG/2021, Dated.14-07-2021.

The Management has requested for issuance of No Objection Certificate for Occupancy to the existing Building of M/s. Kendriya Vidyalaya, Gopannapalem, West Godavari District in the reference 1st cited.

2) The Management has constructed the Building with Ground + (02) Upper Floors with a height of 11.50 Mtrs, with a total Built-up area of 4473.20 Sq. Mtrs., for Educational Occupancy.

3) The Management has not obtained Provisional NOC from this Department and has now applied for No Objection Certificate for Occupancy.

4) The Inspection Committee has inspected the premises of M/s. Kendriya Vidyalaya, Gopannapalem, West Godavari District on 14-07-2021 and submitted the following report vide reference 3rd cited.

5) Particulars of the Building:-

a)Address of the Building	:	M/s. Kendriya Vidyalaya, Gopannapalem, West Godavari District.
b) Height of the building	:	Total Height:11.50 Mtrs.,
c) No. of blocks/floors	:	1 Block/ Ground + 02 Upper floors.
d) Type of occupancy	:	Educational Occupancy
e)Built up area	:	4473.20 Sq. Mtrs.

6) The Management has provided the following Means of Escape:

Sl.No	Details of Means of Escape	Minimum width Required as per NBC		Provided	
		No.	Width	No's.	Width
1	Internal Staircase	02 Nos.	03.00 Mtrs.	02 Nos.	03.40 Mtrs
2	Ramp	01 No.	01.50 Mtrs.	01 No.	01.80 Mtrs

Contd...2p

7) The details of Occupant Load per unit and exit width required and provided are furnished below

Sl. No.	Floor	Built up area in Sq. Mtrs.	Type of Occupancy	No. Of Occupants as declared by the Management	Aggregate width of staircases/ Doors Required in Mtrs.	Aggregate width of Staircases/ Doors provided by the Management in Mts	Deficit
1.	Ground	1507.50	Educational	377	2.45	Provided sufficient No. of doors	Nil
2.	First	1482.85	Educational	371	3.71	5.20	Nil
3.	Second	1482.85	Educational	371	3.71	5.20	Nil
Total:		4473.20					

8) The Management has provided the following Fire Fighting Equipment required as per Table 7 Part 4 of NBC of India 2016.

Sl.No	Fire Fighting System	Required as Per NBC	Provided by the Management	Deficit
1	Fire Extinguishers	34 No's.	34 No's.	Nil
2	Hose Reel	09 No's.	09 No's.	Nil
3	Four way Collecting Head	NA	01 No.	Nil
4	Manually Operated Electrical Fire Alarm System	NA	01 No.	Nil
5	Terrace Water Tank	10,000 Ltrs	75,000 Ltrs	Nil
6	Booster Pump- 450 LPM	450 LPM	900 LPM (02 Nos.)	Nil

9) The Management has paid the following Challan:

Sl.No.	Challan No.& Date	Fire Precautionary Fee	Treasury
1	51070356982021, Dated.11-06-2021	Rs.1,35,118/-	CFMS Payment

10) The Management has provided minimum Fire Safety Measures as per table-7 of Part-IV of NBC-2016 and the inspection committee has tested the provided fire safety systems and found in working condition.

11) The Management is responsible all risks involved in case of Fire Accident.

12) Basing on the report of Inspection Committee the No Objection Certificate for Occupancy is hereby issued to the Existing Multi Storied Building of M/s. Kendriya Vidyalaya, Gopannapalem, West Godavari District.


13) It is informed that, the Management M/s. Kendriya Vidyalaya, Gopannapalem, West Godavari District is requested to maintain the following conditions compulsorily for safety purpose.

Contd...3p

Sl.No.	As Builder	As occupant	As Security Personnel
1	All the fire protection arrangements shall be maintained in good condition as seen during inspection.	All the escape/exit routes shall not be kept locked/blocked or encroached	All the occupants must know the correct method of operation of the fire fighting system installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management.	All occupants shall be trained to operate the fire safety equipments during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition / alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipments during emergency.
4	This No objection Certificate for occupancy is valid for one year from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows.

14) This No Objection Certificate for Occupancy is valid for a period of (05) years only from the date of issue of this letter. It is the responsibility of the builder to apply for Renewal of No Objection Certificate for Occupancy, duly remitting the User Charges as per G.O.Ms.No.169, Home (Prisons & Fire) Department, Dated.19-12-2019, before expiry of this No Objection Certificate.

Yours Sincerely,



Director General,
State Disaster Response and Fire Services
Andhra Pradesh, Vijayawada.

Copy to the M/s. Kendriya Vidyalaya, Gopannapalem, West Godavari District.
Copy to District Fire Officer, West Godavari District.

Note: In case of any emergency call to 101 or State Fire Control Room-9100108101.