

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2024/SZ/356

Dated: 26/04/2024

FIRE SAFETY CERTIFICATE

Certified that the Kendriya Vidyalaya, CRPF Camp, Jharoda Kalan, New Delhi-110072, comprised of Two wings namely Primary Wing & Secondary Wing. Each wing having ground plus two upper floors. owned/occupied by Kendriya Vidyalaya Sangathan was issued Fire Safety Certificate by this department vide letter no. F.6/DFS/MS/School/2012/4272 dated 15/11/2012. The School building was re-inspected by the officer concerned of this department on 10.04.2024 in the presence of Sh. Sunil Kumar (Principal) and found that School building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class educational with effect from 26/04/2024 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....26/04/2024..... at New Delhi.

(Aul Garg)
Director
Delhi Fire Service

Copy to:-

1. The Principal, Kendriya Vidyalaya, CRPF Camp, Jharoda Kalan, New Delhi-110072.
2. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi - 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. There shall not be more than 45 children in the classrooms having single door.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.



भारत सरकार

केन्द्रीय लोक निर्माण विभाग

कार्यपालक अभियंता, निर्माण मंडल-4

के.लो.नि.वि., आई.ए.आर.आई. पूसा, नई दिल्ली-110012

दूरभाष: 25841056, ई-मेल: cccd4cpwd@gmail.com

संख्या: 11(2)/का.ई./नि.म.-4/2023-24/2863


दिनांक: 11-12-23

BUILDING SAFETY CERTIFICATE

Certified that the existing building Kendriya Vidyalaya, CRPF, Jharoda Kalan, New Delhi at Group Centre, CRPF, Jharoda Kalan, New Delhi - 110072 comprised of Nil basement and three upper floors) owned by Kendriya Vidyalaya, CRPF, Jharoda Kalan have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of CPWD, New Delhi on 02.12.2023 (date of inspection) in the presence of Dr. Sunil Kumar, Principal, Kendriya Vidyalaya, CRPF, Jharoda Kalan and that the building/premises is fit for occupancy upto classes XII with effect from 11.12.2023 for a period of One year in accordance with rule and subject to compliance of the specific conditions as appended.

1. Repair of ceiling required of 06 nos. toilet blocks in primary wing.
2. Special/Structural repair required of school building.

For above works preliminary cum detailed estimate already submitted vide letter no. 11(2)/का.ई./नि.म.-4/2023-24/1704 दिनांक: 02.08.2023 and till date A/A & E/S awaited from client department.


Executive Engineer
CD-IV, CPWD,
IARI, Pusa, New Delhi.

NO : CBSE/2700011/EX-05747-2425/2024-25/

Dated: 15/09/2023

The Principal,
KENDRIYA VIDYALAYA CRPF CAMP JHARODAKALAN N D
C R P F CAMP, JHARODAKALAN
DELHI, NEW DELHI, 110072
(M: -28013500)

SUBJECT: -Extension of Regular Affiliation up to Senior Secondary Level.

This is with reference to school application on the subject cited above. In this connection, I am directed to convey the approval of the Board for Extension of General Affiliation as per details given below:-

Affiliation No used as User ID for both OASIS and LOC/Registration System	2700011
School No	29031
Affiliated for	Extension of Regular Affiliation
Category	Extension of Affiliation
Period of affiliation	01.04.2024 to 31.03.2029

The above sanction is subject to fulfillment of following conditions:-

- The approval is based upon the documents /data/information uploaded by the school online. The school will be responsible for its genuineness. In case of any discrepancies, necessary action will be initiated against the school as per Affiliation Bye -Laws-2018.
- The school shall follow all the provisions of Affiliation Bye-Laws- 2018, Examination Bye-Laws, circulars, guidelines, instructions and other amendments issued from time to time by the Board.
- The School shall possess following valid mandatory documents at all times :
 - No Objection Certificate
 - Recognition Certificate
 - Land Certificate
 - Fire Safety Certificate
 - Building Safety Certificate
 - Certificate of Registration of Society/Trust/Company
 - Safe Drinking Water and Sanitary Condition Certificate
- The School shall also ensure the compliances with the Board's Bye-laws in respect of following facilities and infrastructure within 3 months and submit compliance on SARAS portal.
 - Boundary Wall: Concrete boundary wall of not less than 6 ft. height, enclosing the school campus/site. Composite boundary walls which are partly concrete and partly grill/mesh/barbed wire below 6 feet will not be acceptable. If fencing/grill is required, then the same should be over and above 6 feet height.
 - Ramps at the entrance(s) as well as Ramps/lifts for CWSN, to access the upper floors of the school (in case of a multistoried school) (Circular No. CBSE/AFF-05/2023 dated 06.03.2023).
 - Separate toilets for CWSN, boys and girls on every floor (in case of multistoried schools) (Circular No. CBSE/AFF-05/2023 dated 06.03.2023).

4. Appropriate laboratory infrastructure for Secondary School (Composite Science Lab, Mathematics Lab, Computer Lab) and for Senior Secondary School (Composite Science Lab, Mathematics Lab, Computer Lab, Physics Lab, Chemistry Lab, Biology Lab.) (Circular no. CBSE/AFF-11/2022 dated 04.10.2022)
5. Well stocked library with adequate reading area. (Circular no. CBSE/AFF-11/2022 dated 04.10.2022)
6. Well-developed indoor and outdoor sports facilities. (Circular no. CBSE/AFF-11/2022 dated 04.10.2022)
7. Well-developed Digital Infrastructure (Circular No. CBSE/AFF-10/2023 dated 24.03.2023)

Failure to comply within the prescribed time may invite financial penalty @ 50,000/- per month until compliance is submitted and may debar the school from filling the registration and LOC of students' class IX to class XII, as the case may be.

If the compliance is not submitted within the stipulated 3 months, the Board may enhance the penalty amount and debar the schools from filling up registration/LOC details of students of classes IX to XII, as the case may be, in the next academic session i.e. 2024-25.


DEPUTY SECRETARY/JOINT SECRETARY (AFF.)

Note :-

1. The School is required to apply online for extension of affiliation before its expiry along with the requisite fee and other documents as per Rule 10.3 of Affiliation Bye Laws.
2. The school will follow the RTE Act, 2009 and instructions issued thereon by the CBSE/Respective State /UT Govt. from time to time. The school will also abide by the conditions prescribed, if any, by the State Government concerned.
3. The school shall be solely responsible for any legal consequences arising out of the use of school name/logo/society/trust or any other identity /activity related to running of school affiliated to CBSE. All legal expenses incurred by the Board, if any, arising out of these circumstances, shall be borne by the school.
4. The school shall not remove the documents and videography links in the mandatory disclosure section of its website.

This is an electronically generated document. It does not need any signature.

*To verify the authenticity of the document, please visit
(<http://www.saras.cbse.gov.in/saras/AffiliatedList/ListOfSchdirReport>).*



पञ्च प्रमाणिका/सं
Ref No KVS/

To,

Sh. B. B. S. Pachauri,
Technical Officer (W)
Kendriya Vidyalaya Sangathan (HQ)
18, Institutional Area,
Shaheed Jeeet Singh Marg,
New Delhi-110067.

SUB :- REGISTRATION OF LEASE-DEED IN SUB-REGISTRAR OFFICE KAPASHERA.
REF :- TRANSFER OF LAND FOR KENDRIYA VIDYALAYA, CRPF JHARODKALAN,
NEW DELHI.

* * * * *

Sir,

With reference to your letter No. 7-22/B3-KVS/Land/WK-II dated 10.10.2001, on the above cited subject, I am to inform you that lease-deed of Land measuring 04 acres for Kendriya Vidyalaya, CRPF, Jharodkalan has been executed and registered in the office of local sub-registrar at Kapashera.

As desired by you please find herewith the photocopy of the "CRPF LEASE DEED FOR THE DEMISE OF LAND TO KVS."

Instructions for demarkation and further steps to be taken are awaited.

Thanking you,

Yours faithfully,

(R. D. SHARMA)
PRINCIPAL.

Copy to :-

1. The Asstt. Commissioner, KVS(DR)N/D-67 for information please.
2. Mr. A. K. Saxena, Executive Engineer, KVS(HQ)N/D-16 for information please.

(R. D. SHARMA)
PRINCIPAL.

Phone/दूरभाष } 5315359
Fax No. }

केन्द्रीय विद्यालय
Kendriya Vidyalaya

सीआरपीएफो कैम्प, झरोदा कलान, नई दिल्ली-72
C.R.P.F. Camp, Jharoda Kalan, New Delhi-72

दिनांक 6.3.2002

Date.....

KENDRIYA VIDYALAYA SANGATHAN
1st INSTITUTIONAL AREA
SHARAD JET SINGH MARG
NEW DELHI-16.

60
Dated: 10/10/2001

10RS.

6.7-22/83-KVS/Land/WK-II

Principal,
Kendriya Vidyalaya,
CRPF, Jharodakalan,
New Delhi.

Subject:- Transfer of land for Kendriya Vidyalaya, CRPF
Jharodakalan, New Delhi.

Sir,

With reference to the lease-deed papers submitted
by CRPF Officials on 03.10.2001 for the above cited subject,
I am to enclose herewith the fresh lease-deed of land
measuring 04 acres for Kendriya Vidyalaya, CRPF, Jharodakalan,
duly signed by the Joint Commissioner (Admn), KVS for
further necessary action.

You are requested to get it registered in Local
Sub-Registrar Office after completing other necessary
formalities. A photocopy of executed Registered lease-deed
may be sent to this office for record please.

An early action is requested.

Yours faithfully,

(Signature)
(B.B.S. PACHAURI)
Technical Officer (W)

Copy for information and necessary action to:-

1. The Chairman, VMC, K.V. CRPF Jharodakalan, N. Delhi.
2. The Assistant Commissioner, KVS (RO) Delhi.

Technical Officer (W)

46
25/1/02



DEED 20061998123024
VANDYKE, JAMES E. (WV2)
made this 28th Jan

This lease made this 28th Jan..... day of 2002..... of the year two
of India acting through IGP CRPF Sector.....

And whereas the lessor has agreed to demise unto the lessee the said land mournfully

20

M.P. HOUSING BOARD, NEW DELHI

HANDING OVER/TAKING OVER NOTE

Description of Building : Construction of "B" type 3 Storey School Building of Kendriya Vidyalaya at CRPF Camp, Jharodakalan, New Delhi.

Short Description of Rooms : Principal, 36 Class Rooms, Library, 03 Labs, Computer Room, Toilets etc.

Electrical/Water Supply/Sanitary fixtures : As per list enclosed.

Sanction No. of KVS & date : F.14/2001-KVS/WK-I dated 02/05/2002

Date of Start of Work : 01/01/2003

Date of completion of work : 23/09/2005

Date of Occupation : 05/10/2005

List of defective work found in the school building (Civil/Electrical) on the day of take over is enclosed (Exhibit - I). Original proposal was not made available for the purpose of checking cross-verification. Technical details were checked by Sh. Vijay Behl, JE, CPWD (OLD).

HANDED OVER

(Mukesh Samal) *[Signature]*
Asstt. Engineer
M.P. Housing Board
Sub Division New Delhi.

(Vijay Behl)
JE CPWD (OLD)

(Ved Prakash) *[Signature]*
Asstt. Commandant
VMC Member

(Digamber Singh) *[Signature]*
PGT(Geog.)

(Mahkar Singh) *[Signature]*
PGT(Physics)

TAKEN OVER

[Signature]
(MRS. R.K. SHARMA)
PRINCIPAL
Kendriya Vidyalaya
CRPF Camp, Jharodakalan,
New Delhi.

(P. DEVASENA) *[Signature]*

EDUCATION OFFICER, KVS (DR)

... in this clause shall apply to ... on his behalf to set
 and hereunto and the lessee has hereunto set his hand the day and the year first above written.

THE SCHEDULE ABOVE REFERRED TO

All that piece of land measuring 80 x 205 mtr. and parcel of land situated at GC
 RPF Campus, Thanda Kalan (part of) survey number and bounded.

SCHEDULE - I

- On the North by - Main road and bank building
- On the South by - Other land boundary wall
- On the East by - Sol's barrack & mess
- On the West by - Other open land

SCHEDULE - II

S.No.	Description of building	Plinth area	Book Value	Remarks
-------	-------------------------	-------------	------------	---------

Signed by SH. PADMAN SINGH IPS

For and on behalf of the President
 Of India in the presence of:

1. [Signature] Commissioner (Police), N/S.
को. रि. प. बल, आर. के. गुप्त, नई दिल्ली-66
2. [Signature] Deputy Commissioner (Police), N/S.
का. रि. प. बल, आर. के. गुप्त, नई दिल्ली-66

9/11/2001
पुलिस महानिरीक्षक, डी. से.
Inspector General of Police N/S
को. रि. प. बल, आर. के. गुप्त, नई दिल्ली-66
रामकृष्ण (Signature) 1-66.
R.K. Gurab. 1-66

Signed by [Signature] Deputy Commissioner (Police), N/S.
O/o IGP - N/Sector, C.R.P.F.
New Delhi-66

- The lessee, in the presence of:
1. [Signature] प्रमुख, आर. के. गुप्त, नई दिल्ली-110072
 2. [Signature] को. रि. प. बल, आर. के. गुप्त, नई दिल्ली-110072

प्रमुख, आर. के. गुप्त, नई दिल्ली-110072
को. रि. प. बल, आर. के. गुप्त, नई दिल्ली-110072

[Signature] Deputy Commissioner (Police), N/S.
O/o IGP - N/Sector, C.R.P.F.
New Delhi-66

[Signature] Pranlal Singh
Se. T. A.

पंजीकरण प्रपत्र संख्या २)

(Registration Form 2)
पंजीकरण, उप-कार्यालय साउथ-वेस्ट
Sub-Registrar, Sub-Distt -IX, South-West,
KAPAS HERA, New Delhi
Delivery Time : 2.00 PM to 4.00 PM

(पावती - ब)
(Receipt-A)

पंजीकरण
Book No. A

क्रम संख्या 07010
SI No.

लेख प्रस्तुतकर्ता का नाम

लेख निष्पादनकर्ता का नाम

और निष्पादन की तारीख

Name of the executant and date
of execution of the document

प्रलेख प्रस्तुत करने की तारीख

व प्रलेख का स्वरूप और प्रतिदेय

की रशि

Date of presentation nature and
amount of consideration of document

मुद्रांक शुल्क

Stamp duty

प्रमाणित पंजीकरण का विवरण

व जोर और उसके प्रतिनिधि

Details total of registration
copying fee charge

शब्द संख्या

No. of words

रशि

Amount

हस्ताक्षर पंजीकरण अधिकारी

Initials of the Registration officer

GC, CRPF, JHARODAKALAN, NEW DELHI-72
Dated, the Jan, 2002
GC-Bldg

Principal,
Vidyalaya,
Campus,
Jharodakalan, New Delhi

COPIES OF LEASE DEED DULY REGISTERED

find enclosed herewith a lease deed duly
registered at the registration office, Kapashera, New Delhi for
execution.

Yours faithfully,

For Addl. DIGP, GC, CRPF, N/Delhi

Dated, the Jan, 2002

GC-Bldg

Forwarded to the Executive Engineer (Civil),
Jharodakalan, East Block No. 3, R.K. Furam, New
Delhi-7, is required to be handed over to Kendra,
CRPF, Jharodakalan, New Delhi. Hence, please
arrange for demarkation of 4 acres land to be
handed over to the Executive Engineer (Civil),
Jharodakalan, GC Camp, CRPF, Jharodakalan.

For Addl. DIGP, GC, CRPF, N/Delhi

1-2002-

To Principal,
Kendriya Vidyalaya,
CRPF Campus,
Jharodakalan, New Delhi

FORWARDING OF LEASE DEED DULY REGISTERED

Subject :- Please find enclosed herewith a lease deed duly
registered at Registration office, Kapashera, New Delhi for
further necessary action.

Yours faithfully,

For Addl. DIGP, GC, CRPF, N/Delhi

Encl:- 4 (TND)

Jan, 2002

Dated, the

No. KVS-1/2001-2002-GC-31dg

Copy forwarded to the Executive Engineer (Civil),
DAD, CPWD, Level-7, East Block No. 3, R.K. Puram, New
Delhi. 04 acres land is required to be handed over to Kendriya
Vidyalaya, GC Camp, CRPF, Jharodakalan, New Delhi. Hence, please
take necessary action for demarkation of 4 acres land to be
handed over to Kendriya Vidyalaya, GC Camp, CRPF, Jharodakalan,
New Delhi.

For Addl. DIGP, GC, CRPF, N/Delhi

an
ance
ig. th
ted by
request.

... officer
... provisions of the
decision thereon shall be

To hold
in and pay
Delhi or other

the term of 99 (Ninety nine) years commencing from
and yearly ground rent of Rs 1/- at the Reserve Bank of India
place as may be notified by the Lessor for this purpose from time to time

9/11/2001

N/S

OFFICE OF THE ADDL. DIGP, GC, CRPF, Jharkhand
No. KVS-1/2001-2002-GC-Bldg

Dated, 7/1/2002

To

The Principal,
Kendriya Vidyalaya,
CRPF, Jharodakalan,
New Delhi-110072

Subject :- TRANSFER OF LAND TO K.V. SANGATHAN : HANDING OVER
OF LAND DEED DOCUMENTS

Please refer to your letter No. KVIK/A-48/2001-2002 dated 7/1/2002.

The land deed documents in respect of K.V.S. Jharodakalan, New Delhi duly signed by the competent authority of CRPF and two witnesses are enclosed herewith for further necessary action please.

Encl:-

✓ Addl. DIGP, GC, CRPF, New

ann
doth
or wl
is mo.
has for
red, to
the pu.
same b
oil and
lessees, I
obtain an
disturbance
standing th
appointed b
land Acquis
final

To-ho
visiting and
New Delhi or a

... 40 time. V

AquaCare
ENVIRONMENTAL LABORATORY
 (An ISO 9001:2015 CERTIFIED LABORATORY)
TEST REPORT

Test Report No : AEL/2312/021
 Sample Receipt Date : 07.12.2023
 Analysis Date : 07.12.2023 to 09.12.2023
 Date of Report Issue : 09.12.2023
 Customer Ref No / Date: Nil

Sample Code No : AEL/12/23/744
 Sample Description : Water
 Sample Quantity : 1 litre
 Sample Condition : Satisfactory
 Sample Detail : Marked as Drinking Water

ISSUED TO:
 The Principal
 Kendriya Vidyalaya CRPF Camp
 Jharoda Kalan, New Delhi

TEST RESULTS

PARAMETER TESTED			IS: 10500-2012 Drinking Water Specification (Second Revision)		
Sl No	PHYSICO-CHEMICAL	UNITS	RESULT	REQUIREMENT (Acceptable Limit)	TEST METHOD
1.	Odour	-	Agreeable	Agreeable	IS: 3025 (Part 03)-1981
2.	Taste	-	Agreeable	Agreeable	IS: 3025 (Part 03)-1981
3.	Turbidity	NTU	0.2	1	IS: 3025 (Part 10)-1984
4.	pH value	-	8.08	6.5-8.5	IS: 3025 (Part 11)-1981
5.	Total Dissolved Solids	mg/l	152	500	IS: 3025 (Part 16)-1984
6.	Total Hardness as CaCO ₃	mg/l	72	200	IS: 3025 (Part 21)-2009
7.	Calcium as Ca ⁺⁺	mg/l	14.4	75	IS: 3025 (Part 40)-1991
8.	Magnesium as Mg ⁺⁺	mg/l	9.6	30	IS: 3025 (Part 46)-1994
9.	Total Alkalinity as CaCO ₃	mg/l	48	200	IS: 3025 (Part 21)-1986
10.	Chloride as Cl ⁻	mg/l	24	250	IS: 3025 (Part 32)-1988
11.	Free Residual Chlorine	mg/l	BDL (DL=0.2)	0.2	IS: 3025 (Part 26)-2021
12.	Sulphate as SO ₄ ⁻	mg/l	5.2	200	IS: 3025 (Part 24)-1986
13.	Fluoride as F ⁻	mg/l	0.13	1.0	IS: 3025 (Part 60)-2008
14.	Total Iron as Fe ⁺	mg/l	0.12	1.0	IS: 3025 (Part 53)-2003
15.	Nitrate as NO ₃ ⁻	mg/l	1.2	45	IS: 3025 (Part 34)-1988
Sl No	BACTERIOLOGICAL		RESULT	REQUIREMENT (Acceptable Limit)	TEST METHOD
1.	Total Coliforms (MPN/100ml)		Not Detected	Not Detected	IS: 1622 -1981
2.	Faecal Coliforms (MPN/100ml)		Not Detected	Not Detected	IS: 1622 -1981
3.	E. coli in 100 ml of sample present/absent		Not Detected	Not Detected	IS: 1622 -1981

BDL= Below Detection Limit. DL=Detection Limit.

Remarks: -

- The above water sample conforms to IS: 10500-2012 Drinking Water Specification (Second Revision) with respect to the tests conducted.
- The results relate to item tested.

