

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. 276Date : 22.9.2021

It is certified that an inspection team headed by Surentra Kumar Sharma
Junior chemist (Name of Officers
with designation) from PHED Laboratory, Jhunjhunu (Name of
Department/Office) inspected the Kendriya Vidyalaya - Jhunjhunu
(Name & Address of
the School) on 21.9.2021 and found that the Kendriya Vidyalaya
Jhunjhunu (RAJASTHAN) (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of one year.

Surentra
Signature with Seal : (सुरेन्द्र कुमार शर्मा)
कनिष्ठ रसायनज्ञ
Name : जन स्वास्थ्य अभि० विभाग
Designation : प्रयोगशाला, झुंझुनू

To

PRINCIPAL
Kendriya Vidyalaya
Cheru Road - Jhunjhunu
(Name & Address of the Institution)



PUBLIC HEALTH ENGINEERING DEPARTMENT
LABORATORY JHUNJHUNU

CHEMICAL EXAMINATION REPORT OF WATER

No. Lab. / Chem. /2021-22/ 276

Date - 22-09-2021

To,
The Principal
Kendriya Vidyalaya Jhunjhunu


Distt:-Jhunjhunu
Tehsil:-Jhunjhunu

Ref- Your's letter no.30KV/JJN/2021-22 dated 17-9-21

Date of Exam -21-9-2021

| A | Name & Location of Source | | Water Sample Kendriya Vidyalaya |
|--------|--|--------------------|------------------------------------|
| B | Village/ Town | | Jhunjhunu |
| C | Date Of Collection | | 17-9-2021 |
| D | Lab. Sample No. | | C-7 |
| Sr. No | Parameters | Permissible limits | Analysed Value |
| 1 | pH | 6.5—8.5 | 7.3 |
| 2 | Turbidity[NTU] | 5 | Nil |
| 3 | Temperature[C] | ----- | 27.6 |
| 4 | Colour[Units] | 25 Hazen Unit | None |
| 5 | Odour | Unobjectionable | Unobj. |
| 6 | Total Alkalinity[asCaCO ₃] | 600 | 20 |
| 7 | Total Hardness[asCaCO ₃] | 600 | 20 |
| 8 | Calcium Hardness[asCaCO ₃] | | 10 |
| 9 | Magnesium Hardness[asCaCO ₃] | | 10 |
| 10 | Chloride[asCl ⁻¹] | 1000 | 15 |
| 11 | Nitrate[as NO ₃ ⁻¹] | 45 | 2 |
| 12 | Fluoride[as F ⁻¹] | 1.5 | 0.1 |
| 13 | Total Dissolved Solids | 2000 | 60 |

Note: All Results Except pH in mg/L.


(S K Sharma)
Junior Chemist

PHED Laboratory Jhunjhunu

No. Lab. / Chem. /2021-22/

Date -

Copy to -
1-The EE PHED Distt Div Jhunjhunu

(S K Sharma)
Junior Chemist
PHED Laboratory Jhunjhunu