

**MUNICIPAL ADMINISTRATION DEPARTMENT
VENKATAGIRI MUNICIPALITY**

SANIRATY CERTIFICATE

Roc No: 276/2026/F1;

Dt: 30.06.2026

Sub:- Public Health Section – Venkatagiri Municipality – issue of Sanitary Certificate to Kendriya Vidyalaya – Regarding.

Ref:- 1.Application dated: 30.06.2026 of the Principal, Kendriya Vidyalaya, Boppapuram, Venkatagiri Town.

2.Remarks of the Sanitary Inspector, Venkatagiri Municipality, dated: 30.06.2026.

@@@

In view of the remarks submitted by the Sanitary Inspector, Venkatagiri Municipality, it is to Certify that KENDRIYA VIDYALAYA, Boppapuram, Venkatagiri Town. The School has provided portable drinking water, Toilets, Urinals and Electricity facilities.

The Sanitary Conditions of the School are Satisfactory.



Copy to:
The Principal,
Kendriya Vidyalaya,
Boppapuram, Venkatagiri Town,
Tirupati District.


Commissioner,
Venkatagiri Municipality.


30/6/26.
Sr.


30/6/26

**GOVERNMENT OF ANDHRA PRADESH
RURAL WATER SUPPLY & SANITATION DEPARTMENT
WATER QUALITY AND MONITORING LABORATORY**

VENKATAGIRI


REPORT OF PHYSICAL AND CHEMICAL EXAMINATION OF DRINKING WATER

SAMPLE COLLECTED BY & ON	27.06.2026
SAMPLE RECEIVED ON	27.06.2026
HABITATION	Venkatagiri
MANDAL	Venkatagiri
SOURCE & LOCATION	Kendriya Vidyalayam, Boppapuram, Venkatagiri Town
SOURCE CODE	
LAB REF NO	

TEST CHARACTERISTICS OF DRINKING WATER AS PER IS 10500: 2012.

S.No	Parameters	Results	Minimum	Maximum
1	PH Ranges	6.8	6.5	8.5
2	ELECTRICAL CONDUCTIVITY (MICROMOHMS/M ²)	129	0	2500
The Following Results in Miligrams per liters				
3	TURBIDITY	0	1.0	5.0
4	DISSOLVED SOLIDS (Mg/LIT)	84	500	2000
5	ALKALINITY (Mg/LIT AS CA CO ₃)	32	200	600
6	TOTAL HARDNESS AS CA CO ₃	72	200	600
7	CALCIUM AS CA ²⁺	5	75	200
8	MAGNESIUM AS MG AS 2 ⁺	15	30	100
9	CHLORIDES AS CL	42	250	1000
10	FLUORIDE AS F	0.20	1	1.5
11	NITRATE AS NO ₃	7.9	0	45
12	SULPHATE AS SO ₄ IN (Mg/LIT)	1	200	400
13	IRON AS Fe	0.08	0.3	1.0

REMARKS: THE ABOVE WATER SAMPLE IS CHEMICALLY SAFE


Water Analyst
RWS&S Sub-Division
Venkatagiri



GOVERNMENT OF ANDHRAPRADESH
RURAL WATER SUPPLY & SANITATION DEPARTMENT
WATER QUALITY AND MONITORING LABORATORY
VENKATAGIRI SUB - DIVISION

REPORT ON BACTERIOLOGICAL EXAMINATION OF DRINKING WATER

Sample Referred from : ----

Date of report :29.06.2026

Mandal :Venkatagiri

Village:Venkatagiri Town

Source & Location : R.O Water ,Kendriya Vidyalayam,Boppapuram, Venkatagiri Town

Collected by:----

Date of collection :27.06.2026

Date of Receiving :27.06.2026

Lab Reference No :-----

Source Code:-----

RESULTS OF EXAMINATION : BACTERIOLOGICAL

MFT of coli form :0

MFT of E. Coli per 100ml :0

Remarks :The above Water Sample is Bacteriologically Safe.

Alfred
Water Analyst
RWS&S Sub- Division
Venkatagiri