

F-60

12A

Government of Tripura  
Directorate General of Fire Service  
Tripura, Agartala.

Phone: 0381-2326451. Fax: 0381-2324826. Email: [dfireservicetripura@gmail.com](mailto:dfireservicetripura@gmail.com). Website: [www.fireservice.tripura.gov.in](http://www.fireservice.tripura.gov.in)

No. 5625-4/3-8/TFS/2018

Dated, Agartala, the 10<sup>th</sup>, October, 2018.

To  
The Principal,  
Kendriya Vidyalaya, NIT, Agartala,  
At post Jirania, Tripura (West).

Subject :- Installation of the fire safety arrangements in the Building of B+G+2 storied Kendriya Vidyalaya, NIT, Agartala, At post Jirania, Tripura (West) - regarding thereof.

Sir,

Please refer to the above.

It is to inform you that a fire audit team of officers from Fire Service Department have inspected your Institute on 19/09/2018 and found that the existing installed fire equipments are not adequate. They have installed only first aid fire fighting extinguishers. and also found that you have installed 28 nos. CO2 extinguisher having capacity of 4.5 Kg which are in working condition. and out of 17 nos. ABC extinguishers, 11 nos. ABC extinguishers have not in working condition. In respect of fire safety, you are asked to provided the following fire fighting equipments in your Institute as per recommendations of NBC of India, 2016 (Part -4).


A.	<b>School Building:-</b>
1.	11(eleven) nos. ABC extinguisher having capacity of 6 Kg to be refilled immediately.
2.	01(one) no. CO2 extinguisher having capacity of 4.5 Kg to be installed near the main electric panel board area.
3.	Water mist extinguisher having 9 ltrs. capacity - 06 nos. (02 nos. for each floor).
4.	Hose reel system to be installed in each floor 03 nos. each (Ground to 2 <sup>nd</sup> floor) 30 mtrs. long with accessories to be provided.
5.	Terrace level tank -15000 Ltrs. with pump to be fitted for water discharge capacity of 900 LPM with discharge capacity 3.5 Kg/cm <sup>2</sup> .
6.	Automatic sprinkler system to be installed in Library, Office room, Record room.
B.	<b>For SBI Bank :-</b>
1.	02(two) nos. CO2 extinguisher having capacity of 4.5 Kg to be installed for locker.
2.	02(two) nos. Water mist extinguisher having capacity of 9 ltrs to be installed.
3.	15 mtrs. long hose -reel system to be installed with accessories.
4.	Down comer system with landing valve to be installed in the premises.
5.	Manually operated fire alarm with P.A system to be installed.
C.	<b>For Canara Bank :-</b>
1.	03(three) nos. CO2 extinguisher having capacity of 4.5 Kg to be installed for electrical main panel and locker.
2.	02(two) nos. Water mist extinguisher having capacity of 9 ltrs to be installed.
3.	02(two) nos. ABC extinguisher having capacity of 6 Kg to be installed.
4.	15 mtrs. long hose -reel system to be installed with accessories.
5.	Down comer system with landing valve to be installed in the premises.
6.	Manually operated fire alarm with P.A system to be installed.
D.	<b>For Post Office :-</b>
1.	01(one) no. CO2 extinguisher having capacity of 4.5 Kg to be installed for electrical main panel board area.
2.	01(one) no. Water mist extinguisher having capacity of 9 ltrs to be installed.
3.	01(one) no. ABC extinguisher having capacity of 6 Kg to be installed.
4.	Down comer system with landing valve to be installed in the premises.
5.	Manually operated fire alarm with P.A system to be installed.

Contd....P/2.

Therefore, it is advised to take urgent necessary action as recommended by inspecting team mentioned as above within 3(three) month of the receipt of this letter under intimation to Fire Service Department for further verification for issuing Fire Safety Certificate and also advised to engage trained persons to operate the system while in emergency and also to check the equipments time to time. This is to be treated as provisional NOC only which be valid only for 3(three) month. If you fail to comply the order, there will be no option but to report to the Authority of Central Board of Secondary Education (CBSE), Preet Vihar, New Delhi-110 092 to take necessary action.

To avoid any fire incident and to get the Final NOC from this end, an early action in the matter is requested.

Yours faithfully,

  
(Uttam Kr. Bhaumik, IPS)  
Joint Director,  
For Director General Fire Service,  
Tripura, Agartala.

Copy to :-

1. The Divisional Fire Officer, West Division, Agartala for favour of Information. This has a reference to his letter vide No.7329/3-8/FIRE(W)/2018 dated 27.09.2018.
2. The OC, Agartala Fire Station for information.