



Hydel Laboratories (P) Ltd.

Plot No. 2/20, Sec - 2, Rajender Nagar, Sahibabad, Ghaziabad 201005
 0120-4125559, 9319391840 info.hydelaboratories@gmail.com
 support@hydelabs.com Website: www.hydelabs.com

An ISO:9001:2015, ISO:14001:2015, ISO:45001:2018 Certified Laboratory

TEST REPORT

Issued To: Mrigendra Shrivastava Pm Shri Kvafs Rajokri New Delhi-110038.	Report No: 20260905GEN-34 Reporting Date: 10.09.2026 Sample Received On: 05.09.2026 Sampled By: Customer Analysis Start Date: 05.09.2026 Analysis End Date: 10.09.2026 Page No: 01 of 01
Description: Drinking Water Sample Qty.: 2 Ltr.	

TEST RESULTS

TEST RESULTS				REQUIREMENT AS PER IS: 10500-2012	
S. No.	TEST PARAMETERS (With unit of measurement)	TEST RESULT	TEST METHOD	ACCEPTABLE LIMIT	PERMISSIBLE LIMIT
General Parameters: -					
1.	pH Value at 25°C	6.98	IS 3025(P-11):2022	6.5 to 8.5	No Relaxation
2.	Color, CU	ND(DL-1)	IS 3025(P-4):2021	5 Max.	15 Max.
3.	Sulphate, (as SO ₄), mg/l	10.6	IS 3025(P-24/Sec-1):2022	200 Max.	400 Max.
4.	Magnesium, (as Mg), mg/l	8.9	IS 3025(P-46):2023	30 Max.	100 Max.
5.	Turbidity, NTU	ND(DL-1)	IS 3025(P-10):2023	1 Max.	5 Max.
6.	Total Hardness (as CaCO ₃), mg/l	74	IS 3025(P-21):2009	200 Max.	600 Max.
7.	Calcium (as Ca), mg/l	14.8	IS 3025(P-40):2024	75 Max.	200 Max.
8.	Chloride (as Cl), mg/l	24.5	IS 3025(P-32):2025	250 Max.	1000 Max.
9.	Residual Free Chlorine, mg/l	ND(DL-0.3)	IS 3025(P-26):2021	0.2 Min.	1.0 Min.
10.	Iron (as Fe), mg/l	ND(DL-0.05)	IS 3025(P-53):2024	1.0 Max.	No Relaxation
11.	Fluoride (as F), mg/l	ND(DL-0.05)	IS 3025(P-60/Sec-1):2023	1.0 Max.	1.5 Max.
12.	Total Alkalinity, mg/l	52	IS 3025(P-23):2023	200 Max.	600 Max.
13.	Total Dissolved Solid (TDS), mg/l	158	IS 3025(P-16):2023	500 Max.	2000 Max.
Micro Parameters: -					
1.	E Coli, Per 100 ml	Absent	IS 15185 :2016	Shall not be detectable in any 100ml sample	
2.	Total Coliform, Per 100 ml	Absent	IS 15185 :2016	Shall not be detectable in any 100ml sample	

Note: N.D- (Not detected), Values enclosed in brackets are the detection limit.

Remarks: -The sample confirms to IS: 10500-2012 with respect to above tests only.

End of Report

Reviewed By



बिना होलोग्राम के रिपोर्ट
मान्य नहीं है



Note:- • The result indicated only refer to the tested samples and listed parameters and do not endorse any product.
 • Total liability of the laboratory is limited to the invoiced amount.
 • This certificate shall not be reproduced wholly or in part without prior written consent of the laboratory.
 • Samples received shall be destroyed after four weeks from the date of issue of the certificate unless specified otherwise.
 • This certificate shall not be used in any advertising media or as evidence in the Court of Law without prior written consent of the laboratory.

Branch Office: Dehradun(UK)

Patna (Bihar)

Ranchi (Jharkhand)