



# SRM FIRE PROTECTION&SAFETY PVT.LTD.,

44-15-102 LENIN, NAGAR GUNADALA, VIJAYAWADA 520004

☎ CONTACT : 8712113747, 9398802194

✉ EMAIL : SRMFIRESAFETY@GMAIL.COM

## CERTIFICATE

DATE 05/08/2026

Client name: **THE PRINCIPAL, KENDRIYA VIDYALAYA, TENALI**

Report NO :- SRM:286

This is certify that the under mentioned fire extinguisher have been serviced/refilled by us and are Warranted for a period of one year from the date of service.

| SL.NO | PRODUCT NAME | SERIAL.NO | YEAR OF REFILL FX DATE | NEXT DUE ON DATE | TESTED |
|-------|--------------|-----------|------------------------|------------------|--------|
| 01    | ABC 6KG      | 1882      | 05-08-2026             | 04-08-2027       | GOOD   |
| 02    | ABC 6KG      | 2661      | 05-08-2026             | 04-08-2027       | GOOD   |
| 03    | ABC 6KG      | 1961      | 05-08-2026             | 04-08-2027       | GOOD   |
| 04    | ABC 6KG      | 2002      | 05-08-2026             | 04-08-2027       | GOOD   |
| 04    | ABC 6KG      | 1960      | 05-08-2026             | 04-08-2027       | GOOD   |
| 04    | ABC 6KG      | 1963      | 05-08-2026             | 04-08-2027       | GOOD   |
| 05    | ABC 6KG      | 2662      | 05-08-2026             | 04-08-2027       | GOOD   |
| 06    | ABC 6KG      | 2663      | 05-08-2026             | 04-08-2027       | GOOD   |
| 07    | ABC 6KG      | 2664      | 05-08-2026             | 04-08-2027       | GOOD   |
| 08    | ABC 6KG      | 2665      | 05-08-2026             | 04-08-2027       | GOOD   |
| 09    | ABC 6KG      | 2666      | 05-08-2026             | 04-08-2027       | GOOD   |
| 10    | ABC 6KG      | 2667      | 05-08-2026             | 04-08-2027       | GOOD   |

The above said extinguisher has been supplied to the above refer client vide our Invoice NO:-N/A

**Date:05-08-2026 Expiry date:04-08-2027.**

We also certify that the above extinguisher are hydraulically tested 100% at 35 Bar found satisfactory & that one no of fire extinguisher was randomly tested for performance & found satisfactory as per.

For SRM FIRE PROTECTION&SAFETY PVT.LTD

