

Speed 1057



सत्यमेव जयते

भारत सरकार / Government of India
केन्द्रीय लोक निर्माण विभाग / Central Public Works Department
कार्यपालक अभियंता का कार्यालय / Office of the Executive Engineer
हैदराबाद केन्द्रीय मंडल-IV / Hyderabad Central Division - IV
१३३, पहला मंजील, केन्द्रीय सादन / 133 & 134, 1st Floor, Kendriya Sadan
सुल्तान बाजार, कोठी, हैदराबाद-५०००९५ / Sultan Bazar, Koti, Hyderabad-500 095



No.25(KV-Ghatkesar)/2024-25/EE/HYD-IV/1024

Date: 01/07/2024

To

The Principal,
Kendriya Vidyalaya,
NFC, Nagar,
Ghatkesar, Hyderabad.

Sir,

Sub: Issue of Building Safety Certificate for School Building for Kendriya Vidyalaya
at NFC, Ghatkesar, Hyderabad, Telangana State.-Reg.

Ref: Lr. No. F.3-15/2024-25/KVNFC/423, dated:- 25.06.24

With reference to the cited above letter, it is to state that the School building was constructed adhering to all the relevant IS Codes, CPWD specifications and quality control parameters and the building is "Structurally sound and safe for conducting the classes.

For longevity of the building, the regular maintenance like cleaning of terraces, replacement of rain water pipes, internal & external painting, patch repairs, extension joint etc is required to be done.

It is also observed that leakage in boys and Girls toilet block from upper floor. This structural stability certificate is valid for one year from the date of issue of this certificate.


Assistant Engineer

KCSD, CPWD, Karimnagar


Executive Engineer,

HYD-IV, CPWD, Hyderabad.

अवाक INWARD
पत्र नं./Letter No. 325
दिनांक/Date: 04/07/24
हस्ताक्षर/Signature

श्री. राजेश
उपनिरीक्षक
04/07/2024