

AFNET: 4112 7222
Mb :- 9121815101

Academy Fire Section
Air Force Academy
Hyderabad – 500043


AFA/2653/23/Fire

12 Jun 2023


The Principal
Kendriya Vidyalaya No. 2
Air Force Academy
Hyderabad – 500043

FIRE AUDIT REVIEW: K.V.2

1. Reference is made to your letter No. F.SI.No 18/K.V.2/AFA/2022-23/2245/102 dated 02 Feb 2023.
2. Annexed, please find the Fire Audit Review Certificate in respect of K.V.2, AFA.
3. This is for your information and further necessary action, please.


(Mukesh Pal)
JWO
Acy Fire Offr

Annexure: As stated



57. 12/06/2023

FIRE AUDIT REVIEW CERTIFICATE

1. Air Force Academy Fire Section provides assistance to KV No. 2 AFA in case Fire Emergencies.
2. On 23-05-2023, Academy Fire Section has carried out Fire Audit of KV No. 2 to assess the Fire Safety Measures. Following Main points:-
 - (a) KV No. 1 / KV No. 2 is equipped with 06 fire points with the following First Aid Fire Fighting Appliances:-
 - (i) Water CO2 Extinguishers - 01
 - (ii) 2 Kg CO2 Extinguishers - 02
 - (iii) 4.5 Kg CO2 Extinguishers - 02
 - (iv) 9 Ltr Foam Extinguisher - 01
 - (v) 9 Kg ABC Extinguisher - 01
 - (vi) 10 Kg DCP Extinguisher - 01
 - (vii) Fire Buckets - 11
 - (b) Apart from this, KV No. 2 is equipped with Qty - 4, 01 Kg Cease Fire Extinguisher
 - (c) These appliances are inspected every month by Academy Fire Section to check the serviceability
 - (d) Fire lecture and demonstration of fire appliances is carried out on quarterly basis for school staff and students
 - (e) All the electrical fittings are being maintained and checked half yearly by Academy Fire Section along with MES Staff
 - (f) In case of major fire, 02 static water tanks of capacity of 45,000 Ltrs and 67,500 Ltrs are located within 01 Km distance. Academy Fire Section is located within the vicinity of 2 Kms.
 - (g) In case of any Major fire, the school building has entry / exit gates for Domestic Fire Tenders.
3. However, Kendriya Vidyalaya No. 2 does not have any Fire Alarm System and Hydrant System in the School.
4. Adequate Communication facilities exist between the school and the fire section of Air Force Academy.
5. Nearest Fire Brigade of Telanagana State Government is located in Jeedimetla, which is 18 kms away from School.




Academy Fire Officer