GOVERNMENT OF TELANGANA
FIRE, DISASTER RESPONSE, EMERGENCY & CIVIL DEFENCE DEPARTMENT

From
The District fire officer,

Khammam District.

To,
KAVINDRA RAI,
KENDRIYA VIDYALAYAVILLAGE-PELEPALLY
NEAR KARUNAGIRI KHAMMAM TELANGANANEAR
SAI BABA TEMPLE,

Ack. No.**675960002026** Dated:**27/06/2026**

Sir,

Sub: Telangana Fire, Disaster Response, Emergency & Civil Defence Department —Khammam District. Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building of **kendriya vidyalaya khammam,village pollepalli karunagiri by pass road khammam 507003 telangana/-Polepally/Khammam (Rural)/Khammam** , – Regarding.

Ref:
1. Acknowledgement No **675960002026**
2. This Office NOC for Occupancy Ack/RC No.**385260002021** dt.**27/06/2026**
3. Non Multi storeyed Building Inspection Committee Report,. Ack. No. **675960002026**, dt. **27/06/2026**

***** ***** *****

1) The Non Multi storeyed Building Inspection committee, vide reference cited (3) has inspected the Non Multi storeyed Building of **kendriya vidyalaya khammam,village pollepalli karunagiri by pass road khammam 507003 telangana/-Polepally/Khammam (Rural)/Khammam**

2) The above said building was issued was issued No Objection certificate vide reference cited (2) for Non Multi storeyed Building with **1 Ground, 1 Floors,** with a height of **7.00** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy .

3) Now the Builder/Authorized person has requested to issue Renewal of No Objection Certificate for Occupancy to the Non Multi storeyed Building with **1 Ground, 1 Floors,** with a height of **7.00** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy

4) Open Spaces:The builder provided the following open spaces all around the building.

	Sl.No	Side	Open spaces as per Noc occupancy	Open spaces provided now
a	1	North	6.00	6.00
	2	South	6.00	6.00
	3	East	6.00	6.00
	4	West	6.00	6.00
b	Sl. No	Gate Width As per Occupancy NOC	as per Noc occupancy	provided now
	1	Entry gate width	5.50	5.5
	2	Entry Gate Head Clearance	5.50	5.5
	3	Exit Gate Width	5.50	5.5
	4	Exit Gate Head Clearance	5.50	5.50

5) Travel Distance

Sl. No.	Item / Description	as per Noc occupancy	provided now
1	Farthest point (Most Remote Point) With in a storey or a mezzanine floor to the door to an Exit.	30.00	30.00
2	The Dead end of the corridor length in exit access. (6 mtrs for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	6.00	6.00

GOVERNMENT OF TELANGANA
FIRE, DISASTER RESPONSE, EMERGENCY & CIVIL DEFENCE DEPARTMENT

6) Stair Cases (As per Occupancy NOC)

Sl.no.	Type of staircases	Total width	No of staircases	Floors from	Floors to
1	Internal staircases	1.75	2	1st Floor	Ground
2	Ramp(From ground to upper level used as means of escape like in hospitals etc.)	2.00	1	1st Floor	Ground
3	Internal staircases	2.00	1	1st Floor	Ground

7) Means of Escape Floor Wise Details :

Sl.no.	Floor type	Buil-up Area in Sq.Mtrs	Type of Occupancy	Occupant Load	Means of escape required as per Occupancy NOC	Means escape available now
1	Ground	2535.00	EDUCATIONAL B-1 Schools up to senior secondary level	634.00	6.34	7.50
2	1st Floor	2400.00	EDUCATIONAL B-1 Schools up to senior secondary level	600.00	6.00	7.50
	Total	**4935.00**				

8) Fire Shaft as per Occupancy NOC:

9) Floor Wise details of Fire Fighting Installations:

Sl.no	Floor Details	Fire Extinguisher	Hose Reel	Automatic Sprinklers System	Manually Operated Electronic Fire Alarm System	Automate detection and alarm system
1	Ground	13.00	3.00	0.00	0.00	0.00
2	1st Floor	12.00	3.00	0.00	0.00	0.00

10) Fire Fighting Installations As per Occupancy NOC :

Fire Fighting System.	Required As per Occupancy NOC	Provided
Fire Extinguishers	36	36

11). The Non Multi storeyed Building Inspection Committee have reported that the Management has provided the Fire Safety Measres and there is no deficiencies.

12. **Remarks :**

Management applied for renewal NOC to kendriya vidyalaya, khammmam , a educational building (B1)applied for , a ground floor plus one upper floor building and of height 7m located at polepally, khammam rural, khammam. Management provided setbacks and fire protection measures as per occupancy NOC Rc.No.257/A2/2014,24-09-2014 and latest Renewal NOC with Ack no. 38526002021, 07/03/2021.Means of escape is provided as per part-IV of NBC-2016 Hence approved

13) In view of the above and as per recommendations of the Non Multi storeyed building inspection Committee, the Renewal of No Objection Certificate for occupancy is issued to Non Multi storeyed Building with **kendriya vidyalaya khammam,village pollepalli karunagiri by pass road khammam 507003 telangana/-Polepally/Khammam (Rural)/Khammam**

with a height of **7.00** Meters for **EDUCATIONAL B-1 Schools up to senior secondary level** Occupancy subject to the following conditions

Sl No	Builder and Management Body	Occupant	Management Body and fire and security personnel
1	-a) All the fire protection arrangements shall be maintained	All the escape/exit roots shall not be kept locked/blocked or	All the occupants must know the correct method of operation of the fire fighting

	in good condition as seen during inspection. -b) Do's and Don'ts in case of fire shall be prominently displayed in entire building	encroached	systems installed.
2	Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibility of the management.	All occupants shall be trained to operate the fire safety equipment during emergency.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.
3	Addition alteration, if any in the building may be verified by building authority.	Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.	All security personnel shall be trained to operate the fire safety equipment during emergency and guiding the occupants in safe evacuation. Call the fire Brigade by dialing 101.
4	This No objection Certificate for occupancy is valid for Five Years from the date of issue of this letter.	Raise the alarm if the fire cannot be controlled, evacuate the area completely at once from the nearest safe exit.	Attack the fire using available fire equipment only if you feel capable of controlling it. If not, take all steps to isolate the area by closing doors and windows.

This Renewal of No Objection Certificate for Occupancy is valid for Five Years from the date of issue of this letter. It is the responsibility of the builder to apply for renewal NOC, duly remitting the user charges as per G.O. Ms. No. 71, Home (Prison – A) Department, dated 01-04-2010, two months before expiry of this No Objection Certificate.

Signed By : Mr. B. Ajay Kumar
Designation : District Fire Officer , Khammam
Date : 27-06-2026
Khammam District.

Copies to:
i) The Management
ii) Non Multi storeyed Building Inspection Committee
iii) Copy submitted to Regional Fire officer
iv) Copy submitted to DG fire services

"THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE"