


Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE


No. _____ Dated: _____
It is certified that an inspection team headed by ... Km Meenakshi (Chemist)
(Name of Officers with designation) from ... Uttarakhand Jal Sansthan PHED
inspected the ... Kendriya Vidhyalaya, S.S.B., Srinagar Goshwari
(Name & Address of the school) on ... 20/3/2026 (date of inspection) and on the basis of
Water Test Report (Attached) bearing no. 407/UJS/DLWQTM/2025-26 dated ... 23/3/2026
of DLWQTM, Srinagar Goshwari (PHED Lab) certified that the
Kendriya Vidhyalaya, S.S.B., Srinagar (Name of school) has safe drinking water
facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.

This certificate is valid till ... 6 month


सहायक अभियन्ता
उत्तराखण्ड जल संस्थान
श्रीनगर (गढ़वाल)
Signature with Seal:
Name : Er. Arpit Mittal
Designation : Assistant Engineer
Name & Address of the Office / Department : UJS

To
.....
.....
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


Chemist (Km Meenakshi)
District Level Water Quality Testing
& Monitoring Laboratory
Uttarakhand Jal Sansthan, Srinagar



District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Agency Mohalla, Srinagar,
Pauri Garhwal



TC-1270

TEST REPORT

Name and Address of Organization/ Customer	Kendriya Vidhyalaya, S.S.B, Srinagar Garhwal.		
Test Report ID	407/UJS/DLWQTM/LS/2025-26	Reporting Date	23/03/2026
Date and Time of Sample Received:	20/03/2026 & 11:00AM	Sample Location	Kendriya Vidhyalaya, S.S.B, Srinagar Garhwal.
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTM/UJS/KV-01	Duration of Analysis	20/03/2026 to 23/03/2026

SN	Parameters	Test Method	Result	Requirement (Acceptable Limit) As per (IS 10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternative source
----	------------	-------------	--------	--	--

(U) Organoleptic and Physical Parameters

101.	pH at 25°C	IS 3025 (Part 11)	7.32	6.5 to 8.5	No Relaxation
102.	Total Dissolved Solids (TDS), at 180°C mg/L	IS 3025 (Part 16)	128	500 Max	2000 Max
103.	Turbidity, NTU	IS 3025 (Part 10)	0.85	1 Max	5 Max
104.	Colour, CU	IS 3025 (Part 4)	Less than 01	5 Max	15 Max
105.	Odour	IS 3025 (Part 5)	Agreeable	Agreeable	Agreeable

(V) General Parameters Concerning Substances

106.	Total Alkalinity (as CaCO ₃), mg/L	IS 3025 (Part 23)	76	200 Max	600 Max
107.	Total Hardness (as CaCO ₃), mg/L	IS 3025 (Part 21)	92	200 Max	600 Max
108.	Calcium as Ca, mg/l	IS 3025 (Part 40)	27.2	75 Max	200 Max
109.	Chloride as Cl, mg/L	IS 3025 (Part 32)	7	250 Max	1000 Max
110.	Magnesium as Mg, mg/l	APHA 24 th Ed-3500- Mg Method B: 2023 (Calculation Method)	5.83	30 Max	100 Max

Note:-
 1. The results listed refer only to tested sample and applicable parameters. 2. This certificate is not to be reproduced wholly or in parts for promotional
 publicity or legal purpose without permission of authority of testing laboratory. 3. The samples will be destroyed after Seven days from the date of
 issue of test certificate, unless otherwise agreed with customer. 4. The results apply to the sample as received. 5. The Laboratory is responsible for
 the information provided in the report, except when information is provided by the customer.

**** End of Report****

Review By

(Mr. Harendra Singh)
Chemist

Authorized By

(Er. Pooja Dhanai)
Authorized Signatory
District Level Water Quality Testing
& Monitoring Laboratory
Uttarakhand Jal Sansthan, Srinagar



**District Level Water Quality Testing and Monitoring Laboratory
Uttarakhand Jal Sansthan, Agency Mohalla, Srinagar,
Pauri Garhwal**

TEST REPORT

Name and Address of Organization/ Customer		Kendriya Vidhyalaya, S.S.B, Srinagar Garhwal.	
Test Report ID	407/UJS/DLWQTMLS/2025-26	Reporting Date	23/03/2026
Date and Time of Sample Received:	20/03/2026 & 11:00AM	Sample Location	Kendriya Vidhyalaya, S.S.B, Srinagar Garhwal.
Product Description	Drinking Water	Sample Collected by	Customer
Reference Sample Identification:	DLWQTML/UJS/KV-01	Duration of Analysis	20/03/2026 to 23/03/2026

S N	Parameters	Test Method	Results	Requirement (Acceptable Limit) As per (IS 10500:2012)	Permissible Limit (IS 10500:2012) in the Absence of alternativ source
1.	Residual Free Chlorine, mg/L	APHA 24rd Ed.-4500- Cl-G	Less than 0.2	0.2 Max	1.0 Max

(C) Microbiological Parameters

Parameters	Test method	Results	Requirements as per IS 10500:2012
2. Total Coliform (in 100ml)	IS 15185:2016	Absent	Shall not be detectable in any 100 ml samp.
3. E. coli, (in 100ml)	IS 15185:2016	Absent	Shall not be detectable in any 100 ml samp.

Note:-
1. The results listed refer only to tested sample and applicable parameters. 2. This certificate is not to be reproduced wholly or in parts for promotional or legal purpose without permission of authority of testing laboratory. 3. The samples will be destroyed after Seven days from the date of issue of test certificate, unless otherwise agreed with customer. 4. The results apply to the sample as received. 5. The Laboratory is responsible for the information provided in the report, except when information is provided by the customer.

**** End of Report****

Review By

(Mr. Harendra Singh)
Chemist

Authorized By

(Er. Pooja Dhanai)
Authorized Signatory
Authorized Signatory
**District Level Water Quality Testing
& Monitoring Laboratory**
Uttarakhand Jal Sansthan, Srinagar