



भारतीय प्रौद्योगिकी संस्थान इंदौर
खण्डवा रोड, सिमरोल, इंदौर - 453 552, भारत
Indian Institute of Technology Indore
Khandwa Road, Simrol, Indore - 453 552, India

www.iiti.ac.in

IIT Indore

IITI/IDO/WTP/2026-27


September 03, 2026

Safe Drinking Water Certificate

The PM Shri Kendriya Vidyalaya, IIT Indore is supplied with treated water from Water Treatment Plant (WTP) of IIT Indore.

The quality of treated water is tested at regular intervals both at source and in usage i.e. at WTP and Vidyalaya. The test reports confirm with the relevant standards of IS: 10500 and potable. The report bearing no. DW/26/3710 & TC1620026000000242F dated 03.07.2026 & 05.07.2026 also confirms the same.

It is hereby certified that the drinking water being supplied is **potable and safe for daily use and consumption.**


03/09/2026.
Maintenance In Charge (Civil)
IIT Indore



Enclosures: Copies of test reports are attached.



Water Testing Laboratory
Narmada Project Campus, Musakhedi
Indore M.P. India 452001



TC-16200

Phone 0731-2712846 Email: ee2_narmada@rediffmail.com,
waterlabimc@outlook.com

Test Report

ULR No	TC1620026000000242F	Report Page 1/1	Date 05.07.2026
--------	---------------------	-----------------	-----------------

Customer Name and Address	To, MIC, IIT, Indore	Date of Receipt	02.07.2026
		Date of commencement	02.07.2026
		Date of Completion	05.07.2026

Received Sample Description	WTP Plant Source:-Treated Water Volume 1 liter (Approx) Jari Can In unsealed	Lab reference DW/26/37
-----------------------------	--	------------------------

S.No.	Test	Method	IS-10500-2012			Result
			Unit	Desirable Limit	Permissible Limit	
1	pH at 22.1°C	IS 3025 (Part- 11): 2022	-	6.5-8.5	No Relaxation	8.19
2	Colour	IS 3025 (Part 4) Clause no. 4: 2021	Hazen Unit	5	15	2
3	Odour	IS 3025 (Part- 05): 2018	-	Agreeable	Agreeable	Agreeable
4	Taste	IS 3025 (Part - 07): 2017	-	Agreeable	Agreeable	-
5	Turbidity	IS 3025 (Part 10): 2023	NTU	1	5	0.69
6	Total Dissolved Solids	IS 3025 (Part 16): 2023	mg/l	500	2000	178
7	Sulphate(as So ₄) mg/l, Max	IS 3025 (Part 24) Section 1- 2022	mg/l	200	400	4.71

Note:-

1. The legal liabilities limited up to the analytical charges only.
2. The results are related only to the sample tested.
3. The reports shall not be reproduced except in full without approval.
4. Sample not drawn by the Laboratory.

Report Review By

*** End of Report ***



Water Testing Laboratory
Indore Municipal Corporation Musakhedi Indore (MP) India
Phone 0731-2712846 Email: ee2_narmada@rediffmail.com, waterlabimc@outlook.com

Test Report

Reference No DW/26/3710	Report Page No. 1/1	Date	03.07.2026
Customer Name, MIC, IIT, Indore		Date of Receipt	02.07.2026.
		Date of Commencement	02.07.2026.
		Date of sample Collection if specified	02.07.2026.
Location-WTP Plant Source:- Treated Water Volume 250ml GB unsealed			

S.No.	Characteristic	Method of Test ref. to	Unit	IS-10500-2012	Result
				Requirment	
1	Fecal Coliform Bacteria	IS 1622 - 1981	CFU / 100 ml	Should Not Be Deducted	ND

Note:-

1. The legal liabilities limited up to the analytical charges only.
 2. The results are related only to the sample tested.
 3. The reports shall not be reproduced except in full without approval.
 4. Sample not drawn by the Laboratory.
 5. The result apply to the sample as received.
- Abbreviation 'ND' Not detected, 'BDL' Below Determination limit

Reported by


*** End of Report ***

