

CENTRAL RAILWAY
LETTER NO: KVK01/-



SSE /Works/SUR
DATE 23/04/2024

To,
The principal,
Kendriya Vidyalaya Solapur.

Sub: - Certificate for building safety of Kendriya Vidyalaya central railway, Solapur.

Ref: - 1) Principal Kendriya Vidyalaya letter no फा./2752/Fire Safety /KV (SUR)/2023-24/293 Dated – 11.12.2023

2) APO(Wel)/SUR's letter no सोला/का/कल्याण/कवी/2024 dated – 22.01.2024

With reference to above subject and reference letter number quoted above, under signed has inspected the building of Kendriya Vidyalaya Solapur and found sound and in safe condition. However, crack in lintel of class room no 5 'B' in new building and hair crack are found in plaster of verandah of new building. Plaster is fallen in column of main entrance of new building. Cracks are found at the Junction of roof beam and walls in new building This is for your information & necessary action please.

सी. हेड सन इंजीनियर (वर्क्स)
SSE(WORKS)SUR
मध्य रेल, सोलापूर

C/T Sr.DPO/SUR: For information and necessary action please

Sr. Section Engineer (Works)
Central Railway, Solapur.

C/T DEN/South/SUR: For information and necessary action please.

C/T ADEN/SUR For information and necessary action please.

सी. हेड सन इंजीनियर (वर्क्स)
SSE(WORKS)SUR
मध्य रेल, सोलापूर
Sr. Section Engineer (Works)
Central Railway, Solapur.