



Defence Fire Safety Services

Add- 10, South Harsiddhi, Indore

Contact: 7898003673 Email:-defencefiresafetyservices@gmail.com

REFILLING CERTIFICATE OF FIRE EXTINGUISHER

Certificate No: DFS/MAY/2026

M/s Principal PM Shri KV No.2 BSF Indore

Address: Airport Road, Indore

This is to Certify that we have carried out the Refilling & Services of Following

Fire Extinguisher and also include maintenance, repairs/change of damage parts at the time of service of fire extinguisher as warranty period of 1 year from the date of refilling and also free from any manufacturing defects that properly maintained.

Sr. No	Type	Material	Capacity	Cylinder Sr. No	Work	Remark/ Condition
1	ABC Powder	Mono-ammonium Phosphate+N2 Gas	6 KG	10 Nos.	Refill & Service	OK
Total Refilled Fire Extinguisher						10 Nos.

Note- if in case yellow seal of fire extinguisher found damage/broken warranty will be effect. or it will be laps. further we are certifying that the above equipment's are now in good working condition but necessary periodical maintenance and service is required to put in smooth working at all the time.

Issued Under Fire Protection
Manual's Clauses No. 1,3,4 & 5.

Refill Date:06-05-2026

Next Refill Due Date-05-05-2027

Tested & Issued by
For Defence Fire Safety Services

