

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 574

Dated: 28/04/26

I am certified that an inspection team headed by
Mr. Gajendra Dwivedi Quality Manager/chemist
(Name of Officers with designation)

from UMARIA

PHED

inspected the Kendriya Vidyalay SCL Nawrozabad UMARIA

(Name & Address of the school) on 15/04/26 (date of inspection) and on the basis

of Water Test Report (Attached) bearing no. 01

dated 16/04/26 of UMARIA

PHED Lab

certified that the

Kendriya Vidyalay SCL Nawrozabad

(Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains
the hygienic sanitation condition in the school building & the campus as per norms
prescribed by the Central, State/ U.T. Govt.

This certificate is valid till 01 year

Signature with Seal GAJENDRA DWIVEDI
Name Quality Manager
Designation Distt. Water Testing Laboratory
Name & Address of the Office PHED, Umariya (M.P.)

To PRINCIPLE Kendriya Vidyalay SCL
Nawrozabad UMARIA Distt. UMARIA
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

DISTRICT WATER TESTING LABORATORY

(National Drinking Water Mission)

Public Helth Engineering Depptt. Umaria (M.P.)

Block- KARKELI

Village
NOWROZABAI

Code N0-01

Sr.NO.& Detail of Location

Particular of Sample
 Date of collectin- 15.04.2026
 Date of Analysis-16.04.2026
 Reference:(IF any)

(2) TW LTD IN KENDRIYA SCHOOL NOWROZABAD

Table-2.2 BIS Standard: IS-10500-2012(Second Revision)

	Chareacterisitics	Unit	Acceptable	Cause for Rejection	S.No.-241
	Physical Test				
1	Turbidity	N.T.U.	1	5	1.5
2	Colour	Hazen Units	5	15	2.2
3	Taste		Agreeable	Un Agreeable	Agreeable
4	Odour		Un Objectionable	Objectionable	Un Objectionat
	Chemical Taste				
5	PH	PH Scale	6.5	8.5	6.6
6	Total Alkalinity	Mg/l	200	600	160
7	Chlorides (As Cl)	Mg/l	250	1000	50
8	Arsenic	Mg/l	0.01	0.05	-
9	Magnease	Mg/l	0.1	0.3	-
10	Nitrates (As NO3)	Mg/l	45	45	5
11	Total Hardness (As CaCo3)	Mg/l	200	600	320
	Total Dissolved Solids	Mg/l	500	2000	193
13	Iron (As Fe)	Mg/l	0.3	1.0	0.1
14	Fluorides (As F)	Mg/l	1.0	1.5	0.5
15	Sulphates (As SO4)	Mg/l	200	400	
16	Residual Chlorine	Mg/l	0.2	1.0	NIL
	Bactrological Test				
17	Coliform Organism at 370C	M.P.N./100 ml.	NIL	NIL	NIL

Remark- Valid from 1 Year.


Research Assistant
 District Lab Umaria (M.P)