

N.F.Railway

Office of the  
Asstt. Divisional Engineer-II  
Katihar

Date: 05.10.2021

No.WG/2/K.Vidyalaya/n1

To  
✓ The Principal  
Kendriya Vidyalaya, Katihar

Sub: Safety & Security of School building

Ref: Your L/No 28029/KV/Katihar/2021-22/22 dated 18.05.2021 received  
though DEN/G/KIR's L/No.W/214/School- CS/KIR/W-4 dated  
12.08.2021

In reference to your above subjected letter I have personally inspected the school building visually along with SSE/Works/East/Katihar and found that the structural condition of the building is fit for running school, but the toilets(12 nos.), classrooms etc need minor repairs. Some cracks found in wall, Chajja over windows are broken in some places which require repairing.

Moreover condition of structural members of school building is found satisfactory for running of school.

*05.10.21*  
Asstt. Divisional Engineer/II  
N.F. Railway, Katihar

Copy to :-  
Sr. DEN/IV/KIR :For kind information please.

*[Signature]*  
Asstt. Divisional Engineer/II  
N.F. Railway, Katihar

