



No. F6/DFS/MS/School/NDZ/2024/ 1026

Dated: 16/10/2024

FIRE SAFETY CERTIFICATE

Certified that the PM Shri Kendriya Vidyalaya located at NFC Vigyan Vihar, Delhi - 110092, comprised of ground plus two upper floors, owned / occupied by Kendriya Vidyalaya, was issued FSC vide letter No. F6/DFS/MS/School/2021/NDZ/452 dated 07/07/2021. The School building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and re-inspected by the officer concerned of this department on 04/10/2024 in presence of Dr. Gaya Ravidas (Principal) of the school and that the school building is fit for occupancy class "Educational Building" (Group-B) with effect from 16/10/2024 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 16/10/2024 at New Delhi by.

(ATUL GARG)
DIRECTOR

D/c DELHI FIRE SERVICE

Copy to:-

1. The Principal,
PM Shri Kendriya Vidyalaya, NFC Vigyan Vihar, Delhi - 110092.
2. The Aast. Commissioner,
Kendriya Vidyalaya Sangathan, JNU Campus, New Mehrauli Road, Delhi.

Conditions for the validity of Fire Safety Certificate

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.