



भारत सरकार
केन्द्रीय लोक निर्माण विभाग,
 कार्यालय, कार्यपालक अभियन्ता
 डब्ल्यू-मण्डल,
 के.लो.नि.वि., डी-II, 26-28 किदवाई नगर पश्चिम
 नई दिल्ली:-110023
 दूरभाष नं०:011-20907604
 ईमेल :aiimspd@gmail.com



Office of the Executive Engineer
 W-Division, CPWD,
 D-II, 26-28 Kidwai Nagar West,
 New Delhi -110023
 Tel No: 011-20907604
 Email: deleeaiimspd.cpwd@nic.in

सं० 54 (88)/का.अ./डब्ल्यू-मंडल/2026/1021

दिनांक : 27/7/2026

सेवा में,

✓ प्राचार्य पीएम श्री केन्द्रीय विद्यालय
 एन.एफ.सी. विज्ञान विहार
 विवेक विहार दिल्ली-110092

विषय:- Issuing Building Safety Certificate for the Session 2026-27.

संदर्भ:- 1. Your office letter No. F. CPWD/ K V N.F.C. /2026-27/CPWD dated 29.06.2026.

2. 54 (88)/का.अ./डब्ल्यू-मंडल/2026/980 दिनांक : 17.07.2025

महोदय,

With reference to the above-cited subject and letters, it is submitted that a joint inspection of the school's main building was carried out by the undersigned on 25.07.2026, along with the concerned Assistant Engineer and Junior Engineer.

During the inspection, it was observed that the corridor portion of the building is not structurally safe. Several columns at the ground floor of the main building were found to have developed major cracks, necessitating immediate structural strengthening. These cracks had also been observed and brought to the notice of the school authorities in the previous Building Safety Certificate referred to at Sl. No. 2. In this regard, the Structural Audit Report submitted by Dr. Adil Ahmad, Faculty, Jamia Millia Islamia, New Delhi, has already been forwarded to your office for taking necessary action.

Except for the above-mentioned corridor portion, the remaining part of the building has been found to be structurally safe and sound.

Accordingly, this certificate is issued for the Academic Year 2026-27.

(लोकनारायण सिंह)
 कार्यपालक अभियन्ता
 डब्ल्यू-मण्डल, के.लो.नि.वि

प्रतिलिपि प्रेषित :

1. सहायक अभियन्ता-3, डब्ल्यू-मंडल, के०लो०नि०वि०, नई दिल्ली को सूचनार्थ

कार्यपालक अभियन्ता

भारत सरकार

केन्द्रीय लोक निर्माण विभाग,

कार्यालय, कार्यपालक अभियन्ता
अखिल भारतीय आधुनिकीकरण संस्थान परियोजना मण्डल,
कै.सो.नि.वि., डी-11, 26-28 किदवई नगर पश्चिम
नई दिल्ली-110023
दूरभाष नं०: 011-26254146
ईमेल: allmspd@gmail.com

Office of the Executive Engineer
ALLMS Project Division, CPWD,
D-11, 26-28 Kidwai Nagar West,
New Delhi-110023
Tel No: 011-26254146
Email: delectallmspd.cpwd@nic.in



सं० 54(88)/का. अ./अ.भा.आ.स.परि.मं./2025/980

दिनांक: 17/7/2025

सैना में,

प्राचार्य,

केन्द्रीय विद्यालय न्यू फ्रेंड्स सेंटर,
विज्ञान विहार, निकट विवेक विहार पुलिस स्टेशन,
दिल्ली-110092.

(Email id: kvvigyanviharnfc@gmail.com).

विषय:- Special Repair of School Building and Construction of inside road & toilets of Vidyalaya NFC Vigyan Vihar, New Delhi- Building Safety Certificate reg.

संदर्भ:- Your office letter no. F.N.KV/V.V/2025-26/मघन सुरक्षा/ दिनांक 26.06.2025.

महोदय,

With reference to your above referred letter and based on earlier inspection of the school main building by the undersigned along with Assistant Engineer & Junior Engineer and it was found that in the school corridor area of the building is not safe from structural point of view and many columns of main building at Ground Floor were having major cracks due to which the structural audit and strengthening is immediately required as per report of structural audit of Dr. Adil Ahmad, faculty, Jamia Millia Islamia, New Delhi which was already sent to you vide email dated 07.07.2025. Remaining building is structurally safe and sound.

This certificate is issued for the year 2025-26.

(हरजिन्दर सिंह)

कार्यपालक अभियन्ता

प्रतिलिपि प्रेषित :-

सहायक अभियन्ता-3, अ.भा.आ.स.परि.मं, कै.सो.नि.वि., डी-11, 26-28 किदवई नगर पश्चिम, नई दिल्ली
की सूचनाएं एवं आवश्यक कार्यवाही हेतु।

कार्यपालक अभियन्ता