

"STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"

 Delhi Jal Board	OFFICE OF THE ACWA (RWS & BOTTLING PLANT) DELHI JAL BOARD QUALITY CONTROL DIVISION BOTTLING PLANT, GREATER KAILASH, NEW DELHI-110048	 आज़ादी का अमृत महोत्सव
	 Licence No- CRO/QML-8004282, IS/ISO 9001:2015	

Date:-15/04/2024

### Bacteriological Analysis Report

Ref:- DJB/QCL-RWS/GK-I/FLE-08/FRM-01/06

To,  
M/s Kendriya Vidyalaya,  
Vasant Kunj, Pocket B 5 & 6,  
(Opposite B-3 Market)  
New Delhi-110070

Party's ref. & Date - F./KV/VK/2023-24/426 & 08/04/2024  
Dept. Challan No. & Date - 05 & 08/04/2024  
Date of sample collection - 12/04/2024  
No. of sample(s) - SIX (06)  
Reported on - 15/04/2024

Note: Coliform count at 37°C/100 ml after 48 Hrs.

S. No. as in record	Particulars	Clarity	R/Cl <sub>2</sub> mg/L	Coliform MPN/ 100 ml
P1	Inlet point at Ground floor near II-A	Clear	0.5	0
P2	Tap near Room No.101	Clear	0.25	0
P3	Tap near Room No.202	Clear	0.25	0
P4	Tap near Room No.302	Clear	0.25	0
P5	After RO near Staff Room	Clear	ND	0
P6	Tap inside Canteen	Clear	ND	0

R/Cl<sub>2</sub>= Residual Free Chlorine

Remarks: - The above collected water samples found satisfactory in bacteriological examination.

ACWA (RWS)



T. N. RAI  
ACWA (RWS & BP)  
Delhi Jal Board  
Govt. of NCT of Delhi

Bacteriologist (RWS)

Lab./Tech.