



OFFICE OF THE FIRE OFFICER,
CENTRAL RANGE,
BUXI BAZAR, CUTTACK 753001

**ONE TIME RELAXATION
SCHEME-2020**

**FORM-V
FIRE SAFETY CERTIFICATE**

(See rule-13(3) of the Odisha Fire Prevention and Fire Safety Rules, 2017)

File No. X-2-B-03-2020/CTC.CRL

Certificate No. 06/CR-FPS

Dated: 20.03.2022

This Certificate is valid up to 19.03.2024

(Apply at least three months before expiry)

Certified that the G+2 floors educational building Kendriya Vidyalaya No.-1 over plot No. 103, Khata No. 1/1, CDA, Sector-1, Dist- Cuttack were inspected by the officers of Odisha Fire Service on 18.03.2022 in presence of the authorized person of the said buildings and it has been found to comply with the fire prevention and safety requirements in accordance with the Odisha Fire Prevention and Fire Safety Rules-2017 read with Odisha Fire Prevention and Fire Safety (Amendment) Rules, 2019 and One Time Relaxation Scheme of Odisha Fire Service vide Govt. Notification No. 28550/CD Dt. 28.08.2020 and that the floors of the building are fit from fire safety point of view for occupancy or usage as noted hereunder against each subject to compliance to the conditions as prescribed herein below:

Ground to 2 nd floor	...usage ...	School (Educational)
---------------------------------	--------------	----------------------

CONDITIONS

1. Fire prevention and safety measures and appliances, availability of water supplies and means of access thereto etc provided in the building, should be maintained by the occupier(s) in best repairs and efficient working condition at all times for use by the occupants or the members of the Fire Service or both in the event of outbreak of fire.
2. The setbacks, driveways, entrance gates, exits, staircases, corridors and escape ways should not be changed, obstructed or modified in any way.
3. The occupier(s) shall train all staff and occupants periodically to make them well conversant in use and operation of the fire prevention and safety measures.
4. Fire drills/ rehearsals should be organized at least once in six months by involving local Fire Station.
5. The maintenance of fire safety installation in the building/ premises shall be owner's /occupier's liability as per Rule-16 of OFP & FS Rules, 2017. The owner/ occupier shall maintain the same in good repairs and working condition at all times. Any lapses in fire safety installation during fire incident if any shall end with owner's/ occupier's responsibility.
6. Photocopies of this Certificate should be framed and displayed at all conspicuous places in all lobbies/corridors in the floor of building.



Memo No. 1862 /CR-FPS

Dated. 20 .03.2022

Copy to the Principal, Kendriya Vidyalaya No. 1, CDA, Sector-1, Cuttack for information and necessary action please.


20/3/2022

Fire Officer,

Central Range, Cuttack

Fire Officer
Central Range, Cuttack

Dated. 20 .03.2022

Memo No. _____ /CR-FPS

Copy to the Planning Member, Cuttack Development Authority, Cuttack for information and necessary action.

Sd/-

Fire Officer,

Central Range, Cuttack

Memo No. _____ /CR-FPS

Dated. .03.2022

Copy to the Station Officer, Abhinav Bidanashi Fire Station for information.

Sd/-

Fire Officer,

Central Range, Cuttack

Memo No. _____ /CR-FPS

Dated. .03.2022

Copy submitted to the Chief Fire Officer (SAG), Fire Prevention Wing, Odisha, Cuttack for kind information please.

Sd/-

Fire Officer,

Central Range, Cuttack