



Government of West Bengal

Office of the Divisional Fire Officer

West Bengal Fire & Emergency Services

Station Feeder Road, P.O & P.S Siliguri, District: Darjeeling, Pin – 734005

Memo No.:FSR/0125186240500015

Date : 24-07-2025

From :
Divisional Fire Officer
Darjeeling Division,
West Bengal Fire & Emergency Services

To :
PRINCIPAL
PM SHRIkendriya vidyalaya air force station bagdogra

Sub : Issuance of Fire Safety Certificate for the Single Storied School Building under group Educational in name of PRINCIPAL PM SHRIkendriya vidyalaya air force station bagdogra.

Memo No.:FSR/0125186240500015

This is in reference to your AIN 211892506300007363 dated 04-Jul-2025 regarding Issuance of Fire Safety Certificate for the Single Storied School Building under group Educational in name of PRINCIPAL PM SHRIkendriya vidyalaya air force station bagdogra..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Fire Safety Certificate** for occupancy of the aforesaid building.

Recommendation:

1. Driveway must be free from any type of obstruction for easy movement of Fire Appliances, No Parking board will be allowing on the driveway.
2. To eliminate the risk of Fire Hazards, good housekeeping for both inside and outside of the building will be strictly maintaining.
3. Arrangements shall have to be made for regular checking, testing and maintenance of all the Fire fighting installation in the building by a Licensee agency and to keep those in perfectly good working condition all the times and it should be written in the register.
4. Adequate number of "NO SMOKING" boards should be displaying surrounding the premises.



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892506300007363

5. Existing electrical wiring and installation of whole building should be carefully checking and maintenance regularly by a licensed electrician for any wear and tear at those, particularly wiring on false ceiling and ducts.
 6. A Fire control room including a closed circuit T.V system and Fire alarm panel will have to be install, which observes all floor of the building.
 7. The employees and security staff shall be conversant with installed Firefighting equipments of the building and to operate in the event of Fire and Testing.
 8. First Aid Firefighting system should be providing as per I.S specification.
 9. All the Firefighting Extinguisher should be test once in a year.
 10. If required the old Firefighting system should be replaced with new, the cables will be always laying in M.S conduit pipe continuously bonded to the earth.
 11. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
 12. All employees should be trained to operate the Firefighting equipment of the factory, that they can operate the same in case of exigency.
 13. Mock fire drill and evacuation drill should be done periodically with participation of all officers personnel and security guards.
 14. This Certificate is valid for 3 years from the date of issue.
- A register for the recording of Mock fire drill, evacuation drill ,testing and checking of whole firefighting installation, electrical installation will be maintained & liable to produce the same to the authorized officer of this department on demand.
- Every 3 year Certificate shall have to be obtained from this office about the satisfactory performance of all the fire Firefighting and life safety installation, Failing which the Fire Safety Certificate shall be revoked as per rule 18 of the W.B. Fire Service (Fire Prevention & Fire Safety) Rules,2003.

Valid Upto : 22-Jul-2028

Memo No.:FSR/0125186240500015



Signature valid

Digitally Signed,
Name: DEWAN LENCHHA
Date: 24-Jul-2025 15:40:20
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892506300007363