



**COLLEGE OF FISHERIES**  
 Department of Aquatic Animal Health Management  
 (Previously Dept. of Fisheries Microbiology)  
 Kankanady, Mangalore - 575 002  
 Karnataka, INDIA



Telefax : 0824-2246384 (Off)  
 Mobile : 09900136070  
 Email : fishmicrobiolmangalore@gmail.com

Head of the Department

NO. FCM/AAHM/Rev.Fund/Analysis/2024-25/7

02.08.2024

**SAMPLE DETAILS**

SAMPLE SUBMITTED BY	PM SHRI KENDRIYA VIDYALAYA NO.2, EKKUR, KANKANADY POST, MANGALURU		
TYPE OF SAMPLE	SECONDARY WATER		
ANALYSIS REQUIRED	POTABILITY		
SAMPLE GIVEN BY CUSTOMER/ <del>SAMPLE COLLECTED BY LAB</del>	CONDITION OF SAMPLE	-	
SAMPLE RECEIVED ON	30.07.2024	TEST COMPLETED ON	02.08.2024
REFERENCE STANDARD	IS 10500 : 2012		

**TEST REPORT**

<u>Sl. No.</u>	<u>Parameters</u>	<u>Units</u>	<u>Result</u>	<u>Acceptable Limit</u> (IS 10500 : 2012)
1.	Total coliform count	MPN/100 ml	<2	Shall not be detectable in any 100 ml sample
2.	Faecal coliform count	MPN/100 ml	Nil	

COMMENT: BACTERIOLOGICALLY, THE WATER SAMPLE IS OF POTABLE QUALITY.  
 (SAFE FOR DRINKING)

✓ **Head of the Department**

Department of Aquatic Animal Health Management  
 Karnataka Veterinary, Animal & Fisheries Sciences University, Bidar  
 College of Fisheries, Mangalore - 575 002

Note: This report of analysis is for your information and guidance only and not valid for commercial or legal Purposes