



Assoc. Professor & Head

COLLEGE OF FISHERIES
Department of Aquatic Animal Health Management
(Previously Dept. of Fisheries Microbiology)
Kankanady, Mangalore - 575 002
Karnataka, INDIA



Mobile : 09900136070
Email fishmicrobiolmangalore@gmail.com

NO. FCM/AAHM/Rev.Fund/Analysis/2025-26/45

18.09.2025

SAMPLE DETAILS

SAMPLE SUBMITTED BY	PM SHRI KENDRIYA VIDYALAYA, NO.2, YEKKURU, KANKANADY, MANGALURU - 575 002 (An autonomous organization under the Ministry of Education, Govt. of India)		
TYPE OF SAMPLE	SECONDARY SCHOOL WATER (Ref. No. F 13112/2025-26/MNG2/55, dtd. 16.09.2025)		
ANALYSIS REQUIRED	POTABILITY		
SAMPLE GIVEN BY CUSTOMER/SAMPLE COLLECTED BY LAB	CONDITION OF SAMPLE		-
SAMPLE RECEIVED ON	16.09.2025	TEST COMPLETED ON	18.09.2025
REFERENCE STANDARD	IS 10500 : 2012		

TEST REPORT

<u>Sl. No.</u>	<u>Parameters</u>	<u>Units</u>	<u>Result</u>	<u>Acceptable Limit</u> (IS 10500 : 2012)
1.	Total coliform count	MPN/100 ml	<2	Shall not be detectable in any 100 ml sample
2.	Faecal coliform count	MPN/100 ml	Nil	

COMMENT: BACTERIOLOGICALLY, THE WATER SAMPLE IS OF POTABLE QUALITY.
(SAFE FOR DRINKING)


Associate Professor & Head
Dept. of Aquatic Animal Health Management
Karnataka Veterinary, Animal and Fisheries Sciences University, (Mangalore)
College of Fisheries, Mangaluru - 575 002.

Note: This report of analysis is for your information and guidance only and not valid for commercial or legal Purposes