



BACTERIOLOGICAL TEST							
18	Residual Chloride as Cl <sub>2</sub>	mg/l	0.2	1.0	0.2	<del>          </del>	<del>          </del>
19	MPN of Coliform	Per 100 ml	Nil	Nil	—	<del>          </del>	<del>          </del>
20	Faecal Coliform	Per 100 ml					

Note:- The figures indicated under the column " Requirement (Desirable Limit)" the limit upto which water is generally acceptable to the consumers, Figures in excess of those mentioned under " Requirement (Desirable Limit)" the water not acceptable, but still may be tolerated in the absence of an alternative and better source but upto the limits indicated under column " Permissible limit in the absence of Alternate Source" above which the source will have to be rejected (Guideline values for Drinking water as Per BIS 10500)

*[Signature]*  
 Signature of Analyst  
 Remarks if any

Lab Incharge  
 District Laboratory PHED Rewa (M.P.)

**Chemist**  
 District Laboratory  
 PHED Division Rewa (M.P.)

*[Signature]*  
**प्रधान/Principal**  
 एम. श्री के.के.ओ. 2/एम. श्री.के.व.नो. 2  
 रीवा / Rewa