भारत सरकार/ GOVERNMENT OF INDIA

कंद्रीय लोक निर्माण विभाग/ CENTRAL PUBLIC WORKS DEPARTMENT कार्यपालक इंजीनियर (प्इचेरी) कार्यालय/Office of the Executive Engineer(Puducherry) Nirman Bhawan, JIPMER Campus, Puducherry-6



Nirman Bhawan, JIPMER Campus, टेलिफोन / Telephone : 0413 2272059 फेक्स / Fax : 0413 2275569

ई मेइल / E mail : pyddopcd.cpwd@gov.ln

सं/No.23(36)/EE(Puducherry)/2024/ 573(4)

दिनांक / Date: 12/05/2024

ग्रेवामें/To:

The Principal,

Kendriya Vidyalaya No-2, Kalapet, Pondicherry-605 014.

महोदय/Sir,

विषय/Sub:- Structural Stability Certificate for PM SHRI KV No.2, Pondicherry-Reg.

संदर्भ/Ref:- F.No.180231/PM Shri K.V.No.2 Pondicherry/2024-25/23 Dated: 03/05/2024

Kindly refer to the letter under reference. In this regard the undersigned and Smt. Seetha Lakshmi, Assistant Engineer-I, has inspected PM Shri. KV-2 building premises on 17.05.2024 and structural stability of school building is furnished as below.

This is to certify that the Kendriya Vidyalaya school building located in KV School-2, Kalapet, Puducherry is inspected on 17.05.2024 and found to be structurally safe and stable. The structural stability certificate is issued subject to the following condition.

- It is requested that the user department may periodically inspect the building and if any dampness and or cracks noticed in the building, the same may please be reported to the CPWD or any other Engineering organization for remedial measure.
- Regular maintenance of the building and other leakage shall be carried out to safe guard the structure for the designed perjod of life.
- 3. It is noticed that pressed clay tiles work at main building terrace roof is broken at many places which needs urgent repair and rectification work.
- 4. Wall at Proposed Multipurpose Hall is found damp and crack which needs retrofitting and repair work.
- 5. Plant growth at proposed Multipurpose Hall shall be removed.

Thanking You,

Encl: - Site Photos.

अवदीय/ yours faithfull

(एसरवि / S.RAVI)

कार्यापालकअभियन्ता (पुडुचेरी) / Executive Engineer (Puducherry) के.तो.नि.वि/C.P.W.D., पुदुच्चेरी-605 006 / Puducherry-605006

P.T.O