

**TAMIL NADU FIRE & RESCUE SERVICES**  
**NO OBJECTION CERTIFICATE**  
**FOR SCHOOL**

SL.NO:12/2024  
No: 124/V/2024

DATE: 11.03.2024

Sub: Fire & Rescue Service – Fire & Rescue Station – Triplicane  
Issuing No Objection Certificate to start school to issue  
Approval regarding.

Ref: 1. Govt. Order No.206, School Education (Primary Education 2 (2))  
2. Application receiving date: 06/03/2024  
Reference cited, Govt. order & as per the applications.

Door: ISLAND GROUNDS, CHENNAI-02, Established in above address M/S:  
KENDRIYA VIDYALAYA SCHOOL they said above School inspected by R.MURUGESAN,  
SSO, Fire & Rescue Station Triplicane Date on.08/03/2024 The following Govt. norms should be  
fulfilled by school authority. This NOC valid for ONE Year from the date of issue.

**SAFETY MEASURES**

- (A) This license is valid for one year from the date of issue,
- (B) Fire safety systems should be maintained in good working condition.
- (C) Mock drill to be conducted periodically with the help of local fire brigade.
- (D) Any erection of permanent or temporary structure should be intimated to this department.
- (E) A trained fire service person, preferably retired one should be appointed.
- (F) Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
- (G) Building occupancy capacity should not be more than 4 people per sq.metre as per the national building code 2005.
- (H) The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.
- (I) As per Para 6.3 of the BIS standards: 1997 as the classrooms have only one entrance, the capacity of the class room shall have to be limited to 45 students.
- (J) Periodical maintenance and care should be taken to maintain all fire protection equipment.
- (K) Mock drill has to be conducted at regular intervals in consultation with the division officer, fire & rescue service, Chennai central division at kilpauk.



TO, THE PRINCIPAL,  
M/S: KENDRIYA VIDYALAYA SCHOOL,  
ISLAND GROUNDS,  
CHENNAI-02.

11/03/24  
சிறப்பு நிலைய அலுவலர்  
தீயணைப்பு மற்றும் வீட்டும்பணிகள் நிலையம்  
திருவல்லிக்கேணி, சென்னை - 600 002

Copy: District Officer, Chennai Central District.