

GOVERNMENT OF MEGHALAYA

OFFICE OF THE SUPERINTENDENT OF POLICE, (FIRE & EMERGENCY SERVICES)
MEGHALAYA SHILLONG

L/No.MFS/374/EB/2024/36/ 8159

Dated Shillong the 18^R June 2024

From: Superintendent of Police, (F&ES),
Meghalaya, Shillong.

To: ✓ The Principal,
Kendriya Vidyalaya, Air Force Station,
Laitkor Peak, Shillong.

Sub: **Provisional NOC cum Suggestions for implementation of Fire Safety Measures at Kendriya Vidyalaya, Air Force Station, Laitkor Peak, Shillong.**


Sir,

With reference to the above, I am to inform you that, Fire Safety Audit was carried out at the above mentioned premises on the 11th June 2024 and on the basis of inspection report following observations were made and the same should be implemented at the premises: -

1. All Entry/Exits should be kept open during the School hours to avoid stampede in case of any exigency.
2. Fire Extinguishers should be installed at a height of 1 meter from the floor level.
3. Electrical wirings and fittings should be checked annually and Electrical Safety Certificate should be obtained from the competent authority for producing at the time of Fire Safety Audit.
4. Emergency telephone numbers should be displayed at a conspicuous place and kept up-to-date.
5. The surroundings of the premises should be kept neat and clean.

Fire Safety Certificate will be issued upon implementation of the above suggestions and submission of application online through the website www.investmeghalaya.gov.in

Yours faithfully,


Superintendent of Police, (F&ES),
Meghalaya, Shillong

Superintendent of Police (F & ES)
Meghalaya, Shillong

