GST Number: ***05BTLTB8794F1ZE***

Mob: 9411725625
9557779964

UTTARANCHAL FIRE SECURITY CO.
FIRE PROTECTION SYSTEM

BANGAL ENGINEERING GROUP ROAD RAIWALA, DEHRADUN (U.K)

Ref no. U/F/S.204

Dated:29/01/2025

Hydraulic Pressure Test Certificate

This is to certify that the following fire Extinguisher. I have received the ABC Type fire extinguisher Cap 5kg Nos 13 . ABC type Fire Extinguisher Cap 2kg Nos 08 .Afff foam type fire Extinguisher Cap 9 ltr Nos 01 . Kendriya vidyalaya raiwala Dehradundistt Dehradun .I have been tested hydraulically in our firm premises as per scheduled IS:2190 and test report observed as under :

SI No	Cylinder type	Qty in Nos	Specified	Hold pressure in min.	Result
1.	ABC **2kg**	08 Nos	35 kgf/cm2	35 *kgf/cm2*	**Ok**
2 3.	ABC **5kg** AFFF foam **9lit**	13Nos 01 Nos	35kgf/cm2 35kgf/cm2	35kgf/cm2 35kgf/cm2	**Ok** **Ok**

