

Letter No. 8-10



Dated: 08/02/2025

**SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

It is certified that an inspection team inspected the "PM SHRI Kendriya Vidyalaya Dabra Simariya Taal, Gwalior Road Dabra on dated 08.02.2025 and found that it "PM SHRI Kendriya Vidyalaya Dabra" is providing safe drinking water facilities for the students & staff and is maintaining the hygienic sanitation condition in school building & the campus as per the norms prescribed by the Central/State/UTGovt.

**WATER QUALITY REPORT**

Source.1 Direct bore well

2. Water Tank

| Quantity      | Items      | Remarks |
|---------------|------------|---------|
| Chloride      | 49mg/ltr   | Safe    |
| Sage fluoride | 0.92mg/ltr | Safe    |
| Iron          | 0.53mg/ltr | Safe    |
| TDS           | 220mg/ltr  | Safe    |
| Bacteria      | Nil        | Safe    |

The PH value found is in the range of 7.00 which is safe.

The above is issued for a period of one year from the date of issue.

मुख्य नगर पालिका आधिकारी  
नगर पालिका कार्यालय डबरा