



Govt. Of India
O/o Executive Engineer,
Jammu Division,
Central Public Works Department,
Landol Bridge, Batwari,
Jammu (J&K).
Telephone- 0191-2434505
0191- 2450828

भारत सरकार
कार्यपालक अभियन्ता,
जम्मू मण्डल,
केन्द्रीय लोक निर्माण विभाग,
लखीब्रिज, बतवारी,
जम्मू (जम्मू पूर्व कश्मीर)
दूरभाष - 0191-2434505
- 0191-2450828
e-mail id : ee_jmed@rediffmail.com

SPEED POST



पत्रांक : 20(296)/ज0मं0./2024/1337

दिनांक: 07/08/2024

To

The Principal,
Kendriya Vidyalaya,
Kathua, Janglote Road,
Near Army Cantt. Area,
Kathua - 1841041

विषय : Issue of Building safety certificate regarding.

संदर्भ : Your office letter no. F/1-17/KVK/2024-25/15 dated 16-04-2024

महोदय,

In reference to above, the present condition of Kendriya Vidyalaya Kathua is given as under:-

"It is certified that Kendriya Vidyalaya Kathua is structurally safe and sound".

However, It is to ensure that users have to carryout routine maintenance of the building in timely manner to prevent damage in the structural members.

भवदीय,

(Er. Jai Prakash),
कार्यपालक अभियन्ता,
जम्मू मंडल,
के०लो०नि०वि० जम्मू।

प्रतिलिपि

1. The Assistant Engineer, Jammu Sub Division No. III, CPWD, Samba (J&K) for information w.r.to his letter no. AE-KSD-III/(KV) School Kathua/2024-25/28 dated 03-06-2024.

कार्यपालक अभियन्ता



Office of the Director Fire & Emergency Services, J&K
Jammu/Srinagar

The Principal
Kendriya Vidyalaya
Kathua

No: DFES-FP/9/2022-04(CC-7079422) /199


Dated: 15.06.2024

Sub: Fire Safety Certificate.

Ref: Your online application submission dated: 16.04.2024 (FI028-5878041).

The spot inspection of above said school was got carried out by the inspecting officer of this department. During inspection, it was found that the management has installed Fire Hydrants, Hose Reel Hoses and First Aid Fire Extinguishers in their school premises. Besides this, one underground water storage tank of 100 KL capacity is also available. Moreover, the school is about 06 Km away from Fire and Emergency Station Kathua and is approachable for fire appliances in case of any emergency. Since the school is already functioning, as such, the management can proceed ahead for operation subject to adopt the following fire safety measures/ guidelines in letter and spirit forthwith: -

1. 01 No. CO₂ Type fire extinguisher of 4.5 Kg capacity each should be provided near each electric switch board panel in addition to already existing fire extinguisher.
2. All exit/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmate during any emergency.
3. Manual Operated Electric Fire Alarm System should be installed in the school building.
4. First Aid Firefighting system installed in the school building should be checked periodically. Staff and management should be fully trained in handling / operating of firefighting system installed in the school building.
5. All electric installations existing in the building should be concealed conduit type.
6. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
7. The corridor of the building shall not be used for any kind of storage.
8. No Hazardous material should be kept inside of the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, this clearance will be treated automatically withdrawn/cancelled.
9. The management of the school shall be wholly and solely responsible for keeping the firefighting system in working condition 24x7 and safe evacuation of its students during any mishap.
10. At present school is double storied. As such no addition / alteration should be made by the school management in the existing structure without prior information from this department. Any deviation found in this regard, this clearance will be treated automatically withdrawn/ cancelled.
11. The department can make a surprise visit to your school at any time. During the visit if the firefighting system (i.e. existing as well as proposed) found defunct and deviation, this clearance issued shall be treated automatically withdrawn/cancelled.
12. This clearance shall be subject to outcome of any dispute/investigation/enquiry/trial if any, pending before any Court of Law/Investigation agency. This clearance shall not confirm any title upon the person/company in whose favour it is issued. Further, the status with regard to land shall be the responsibility of the concerned registering authority.
13. The instant clearance is strictly for adoption of fire safety measures/guidelines of the occupancy only and not for authentication of any other claim.
14. The validity of this clearance shall remain in force for one year and same needs to be renew yearly after inspection/checking of entire firefighting system (i.e. existing as well as proposed) installed in the school building. However, before granting permission/ recognition/extension or renewal thereof, the authority concerned shall satisfy himself in terms of conditions laid down in SRO-123 of 2010 and SRO-292 of 2018, issued by Education Department with regard to physical facilities and also ensure the fire safety measures/guidelines given to the proprietor by this department are fully complied with. Moreover, this clearance is exclusively valid for ground floor only where the school is functioning and not for the entire building.


15/06/2024
Director
Fire & Emergency Services, J&K
Jammu/Srinagar

