TC-12273

KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB, THANA, KANNUR
WATER ANALYSIS REPORT

Tele phone No : 0497 2704380
email : kwaqclabkannur@gmail.com

ULR- TC-1227326000003676F

Report No - KWA/QA/R/7/3676/J/71/6515		Date : 10/07/2026
Customer Name and Address	1. Date of receipt	Date : 07/07/2026
Kendriya Vidyalayam **Dharmadam** **P O Thalassery Kannur 670106** **(NON DOMESTIC PURPOSE)**	2. Sampling Provided by	: Customer (QUA_362895)
	3. Sample Code	: 2946B
	4. Sample	: Drinking Water
	5. Source of Sample	: Open Well
	6. Sample quantity & Condition	: 250 ml & Good
	7. Test performing dates From:07/07/2026	To: 08/07/2026

Sl No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Total Coliforms	Detection /100 ml	IS 15185: 2016 (Reaffirmed2021)	Shall not be detected/100 ml	ABSENT
2	*E.coli*	Detection /100 ml	IS 15185: 2016 (Reaffirmed2021)	Shall not be detected/100 ml	ABSENT

Remarks:
The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory

* The Results apply to the sample as received

Reviewed & Authorised By

Febin

BACTERIOLOGIST
QUALITY CONTROL DISTRICT LAB KANNUR
KERALA WATER AUTHORITY
KANNUR 670 012

* End Of Report*