ऑयल एन्ड नेचुरल गैस कारपोरेशन लिमिटेड
OIL AND NATURAL GAS CORPORATION LTD
अग्निशमन सेवायें, अहमदाबाद परिसम्पत्ति
FIRE SERVICES : AHMEDABAD ASSET
अवनि भवन, भूतल, चांदखेड़ा, अहमदाबाद
AVANI BHAVAN, GROUND FLOOR
CHANDKHEDA, AHMEDABAD

Fire Safety Arrangement at KV ONGC Chandkheda

This is to certify that existing fire safety arrangement at Kendriya Vidyalaya, ONGC Chandkheda, Ahmedabad is adequate. Premises has been provided with fixed firefighting hose reel system/external fire hydrants and sufficient quantity of portable fire extinguishers (Water type 9 ltrs -20 nos, DCP ABC Type 4/6 kg - 03 nos, CO2 type 2 Kg-09 Nos, Total-32 nos) are placed at all strategic locations. These are checked quarterly and Fire fighting training/drills are conducted time to time by Fire Services Department of ONGC Ahmedabad for taking prompt and appropriate action by School staff in case of an fire incident. Last training programme on basic firefighting/Mock Fire Drill has been conducted on 19th April 2024.

02/08/2024

(S K Rai)
GM (FS) - I/c Fire Services

संजय कुमार राय
प्रभारी अग्निशमन सेवायें
ओएनजीसी, अहमदाबाद परिसम्पत्ति

FIRE AND EMERGENCY SERVICES
AHMEDABAD MUNICIPAL CORPORATION

FIRE SAFETY CERTIFICATE (FSCA)
(See sub-rule (1) of rule 23)

FSCA NO. 974/2024. Date: 08/08/2024.

To,
Kendriya Vidyalaya ONGC Chandkheda,
Sabarmati, Ahmedabad-380005.
Mobile No: 9968282238
Email id: kumar-mahesh1@ongc.co.in

Building Occupancy/Category: Educational (School)

We Have Received Application **No.1112, Dated.15/07/2024** Along with Supporting Documents for Approval of Fire Safety Certificate (FSC) for the Building/Premise **KENDRIYA VIDYALAYA, ONGC CHANDKHEDA, GF+1 Floor, Building Height: 7.50 MTR.** as per details below-

TP Number: -
FP Number: -
Survey Number: 646 Paiki
Village Name: Sabarmati
Name of Block(s): 1 **(Total No. of Block(s) - 1).**

The application and supporting documents have been verified for compliance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, and related site inspection was carried out on **16/07/2024** which was found satisfactory. The photographs and Videography related to the site inspection is on the portal.

Accordingly, Fire Certificate is hereby approved and issued on 08/08/2024 to 07/08/2027 and is valid a period of three (3) years from the date of issue.

It is the responsibility of the Owner/Occupier to ensure that all fire prevention, life safety and fire protection features and systems provided in the building or premises are maintained in proper and effective working condition and no changes are made to building design and structure (Internal/ external part of building), in event of which the FSC will become null and void.

An Amount of Rs. 41321.00 in word (Forty One Thousand Three Hundred Twenty One Rupees) collected for **FSCA Fee Receipt No. 12/31, Receipt Date. 15/07/2024 (DD No. 328342, MICR No. 000002000).**

Place: Ahmedabad
Date: 08/08/2024

STO Chandkheda
Fire & Emergency Services

AHMEDABAD MUNICIPAL CORPORATION ★ FIRE & EMERGENCY SERVICES ★

I/C Chief Fire Officer
Fire & Emergency Services