

Office of the Director Fire & Emergency Services, J&K
Jammu/Srinagar

The Principal
Kendriya Vidyalaya
Chenani, Udhampur

No: DFES-FP/9/2022-04(CC-7079422) 2169


Dated: 21.12.2023

Sub: Fire Safety Certificate.

Ref: Your online application submission dated:08.12.2023 (F1026-4294286).

The inspection of above said school was got carried out by the inspecting officer of this department. During inspection it was found that the management has installed 02 Nos. of Hose Reel Hose and 19 Nos. of First Aid Fire Extinguisher in their school premises. Besides this, one underground water storage tank of 50 KL capacity is also available. Moreover the school is about 03 Km away from Fire and Emergency Station Chenani and is approachable for fire appliance in case of any emergency. Since the school is already functioning, as such, the management can proceed ahead for operation subject to adopt the following fire safety measures/guidelines in letter and spirit forthwith:-

1. 01 No. of CO₂ Type fire extinguisher of 4.5 Kg capacity should be provided near main electric switch board panel in addition to already existing fire extinguishers.
2. All exit/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmate during any emergency.
3. First Aid Fire fighting system installed in the school building should be checked periodically. Staff and management should be fully trained in handling / operating of fire fighting system installed in the school building.
4. All electric installations existing in the building should be concealed conduit type.
5. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
6. The corridor of the building shall not be used for any kind of storage.
7. No Hazardous material should be kept inside of the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, this clearance will be treated automatically withdrawn/cancelled.
8. One additional emergency exit/staircase should be provided for safe evacuation of students/staff in case of any emergency.
9. The management of the school shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
10. At present school is having two blocks, one is four storey and another is single storey. As such no addition / alteration should be made by the school management in the existing structure without prior information from this department. Any deviation found in this regard, this clearance will be treated automatically withdrawn/cancelled.
11. The department can make a surprise visit to your school at any time. During the visit if the fire fighting system (i.e. existing as well as proposed) found defunct and deviation, this clearance issued shall be treated automatically withdrawn/cancelled.
12. This clearance shall be subject to outcome of any dispute/investigation/enquiry/ trial if any, pending before any Court of Law/investigation agency. This clearance shall not confirm any title upon the person/company in whose favour it is issued.
13. The validity of this clearance shall remain in force for one year and same needs to be renew yearly after inspection/checking of entire fire fighting system installed in the school building. However, before granting permission/recognition/extension or renewal thereof, the authority concerned shall satisfy himself in terms of conditions laid down in SRO-123 of 2010 and SRO-292 of 2018, issued by Education Department with regard to physical facilities and also ensure the fire safety measures/guidelines given to the proprietor by this department are fully complied with.


Director
Fire & Emergency Services, J&K
Jammu/Srinagar



Govt. Of India
O/o Executive Engineer,
Jammu Division,
Central Public Works Department,
Landoi Bridge, Satwari,
Jammu (J&K).
Telephone- 0191- 2450828

भारत सरकार
कार्यालय कार्यपालक अभियन्ता,
जम्मू मण्डल,
केन्द्रिय लोक निर्माण विभाग,
लंडोई ब्रिज, सतवारी,
जम्मू (जम्मू एवं कश्मीर)
दूरभाष - 0191-2450828
e-mail : ee_jmcd@rediffmail.com

SPEED POST



पत्रांक : 20(14)/ज0मं0./2024/2231-H

दिनांक: 07/09/24

To

✓ The Principal,
Kendriya Vidyalaya,
Chenani, Kud,
Distt. Udhampur (J&K) – 182101.

विषय : Safety and Security Certificate of Vidyalaya building – Reg.

महोदय,

In reference to above, the present condition of Kendriya Vidyalaya, Chenani is given as under :-

“It is certified that building of Kendriya Vidyalaya, Chenani (J&K) is structurally safe and sound”.

However, the building requires the maintenance which is required to be done at Top Priority basis to ensure the building life is maintained and building is safe in future. Therefore requisition may be given to department for assessment of require maintenance & subsequently submission of estimate for sanction or same may be got done by Principal KV themselves.

भवदीय,

(Er. Jai Prakash),
कार्यपालक अभियन्ता,
जम्मू मंडल,
के0लो0नि0वि0 जम्मू।

प्रतिलिपि

1. The Assistant Engineer, Jammu Sub Division No. I, CPWD, Satwari, Jammu for information w.r.to his letter no. W(General/KV Chenani/JMSD-I/2024-25/235 dated 30-08-2024.

कार्यपालक अभियन्ता