


GOVERNMENT OF MANIPUR
PUBLIC HEALTH ENGINEERING DEPARTMENT



TO WHOM IT MAY CONCERN

No. EE/TML/PHE/1-95/2025-26/544

Dated: The 23rd Feb, 2026

This is to certify that drinking water available through pipe water supply at Kendriya Vidyalaya School, Tamenglong has been tested and meets all health and safety standards set forth by relevant authorities.

The quality of water is periodically monitored to ensure the health and safety of all the students and staffs.

We are committed to provide a safe and healthy environment for our community

Yours faithfully,

Executive Engineer,
Tamenglong P.H.E. Division,
P.H.E.D., Manipur.

Executive Engineer
Tamenglong P.H.E. Division
P.H.E.D Manipur

TAMENGLONG DISTRICT LAB. PHED, GOVT. OF MANIPUR

TEST REPORT

FF-13
TMLDL/PHED, Manipur
Page No. 1/1

Customer:
ANURAG SHASWAT (Principal I/C)
KENDRIYA VIDYALAYA
Tamenglong District
Manipur - 795141

Email: kvtamenglong2023@gmail.com

Report No. TMLDL/PHED/2026/64
Date of Report: 08-07-2026
Sample ID: 64/07
Date of Collection of Sample: 06-07-2026
Duration of Performance: 06-07-2026 to 07-07-2026
Ref. No. Nil
Date of issue: - 08-07-2026



TC-16562

1	Description of Sample (As declared by customer)	RO Water
2	Sample Mark (if any, given by the customer)	NA
3	Date of Sampling by the Customer	06-07-2026
4	Source & Place of Sampling	Kendriya Vidyalaya, Tamenglong - V
5	Environmental conditions during sampling	NA
6	Sampling Plan & Procedures used	NA
7	Condition of Sample	1 liter in Plastic bottle, Good condition at 4° C

We hereby certify that the following sample submitted to the laboratory has been analyzed with the following results

Analysis Results

Chemical Testing

Sl. No.	Parameter	Acceptable Limit	Permissible Limit	Method of Test	Results		Units
					1	2	
1	Calcium (as Ca)	75	200	APHA 24 th Edition ,3500 Ca B:2023	25.60	28.00	mg/l
2	Chloride (as Cl)	200	1000	APHA 24 th Edition ,4500 ClB:2023	17.00	20.00	mg/l
3	Colour	-	-	APHA 24 th Edition ,2120 B:2023	2	2	HU
4	Magnesium (as Mg)	30	100	APHA 24 th Edition ,3500 Mg Method (By Calculation): 2023	7.29	5.83	mg/l
5	Odour	Ageeable	Agreeable	IS 3025 (PART 8): 2023	agreeable	agreeable	@
6	pH	6.5	8.5	APHA 24 th Edition ,4500- H+ B:2023	6.80	6.82	@
7	Taste	Agreeable	Agreeable	IS 3025(Part 8): 2023	agreeable	agreeable	mg/l
8	Total Alkalinity (as CaCO3)	200	600	APHA 24 th Edition 2320 B: 2023	40.00	42.00	mg/l
9	Total Dissolved Solids	500	2000	APHA 24 th Edition 2540 C: 2023	160.00	240.00	mg/l
10	Total Hardness (as CaCO3)	200	600	APHA 24 th Edition 2340 C: 2023	94.00	94.00	mg/l
11	Turbidity	1	5	APHA 24 th Edition 2130 B: 2023	1.0	1.0	NTU

1. The results relate only to the item(s) tested.
2. This Test Report shall not be reproduced except in full, without the permission of Tamenglong District Laboratory, PHED, Manipur. The reserved part of sample(s) shall be retained for 7days from the date of Completion of Test.
3. The Laboratory is responsible to all the information given in the report.

Reviewed by: -

Latoulung Panmei
Designation: Junior Chemist

Authorized by:-

Latoulung Panmei
Designation: Junior Chemist

----- End of report -----



Annexure – C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.:

Dated:

It is certified that an inspection team headed by

Lataulung Panmei (Junior Chemist) (Name of Officers with designation)

from Tamenglong District Laboratory PHED

inspected the Kendriya Vidyalaya School

(Name & Address of the school) on 06th July, 2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing No. 64/07

dated 07/07/2026 of Tamenglong (PHED Lab) certified that the Kendriya Vidyalaya School (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

This certificate is valid till 31st Decemben., 2026

Signature with Seal: _____

Name: Lataulung Panmei

Designation: Junior chemist



Name & Address of the Office / Department: PHED

To Kendriya Vidyalaya School
Tamenglong - 795141

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies.