

Fire Section
5BRD, AF

5BRD/1501/5/Org (Fire) dt 04 Sep 26

The Principal
PM Shri Kendriya Vidyalaya
AF Station, Sulur

OBSERVATION OF FIRE SAFETY AUDIT

1. Reference is made to your letter No F-2-8/KV-S/AFS/2026-27/Loc 48 dt 02 Sep 26.
2. It is intimated that fire safety audit was conducted on 08 Sep 26 at your premises during the issuance of the fire safety certificate. The audit revealed certain observations as under :-
 - 2.1. Installation of one 3 Kg CO2 fire extinguisher is required to Staff room, Principal room, Office room, Senior computer lab, Language Lab, Chemistry Lab, and Biology Lab.
 - 2.2. Installation of fire alarms and smoke detectors with accessories at prominent locations throughout the school premises.
 - 2.3. Display of Fire Safety Operating Procedures (SOPs) and fire evacuation plans at prominent locations to ensure all staff and students are aware of the necessary actions in case of a fire emergency.
3. You are requested to take necessary action for early rectification of ibid observation and completion report may be issued to this section.
4. Accord priority, please.

(Nandni Sorout)
Flt Lt
Depot Fire Offr

AFNET: 4324-7228

Fire Section
5BRD, AF

5BRD/1501/5/Org (Fire) dt 09 Sep 26

The Principal
PM Shri Kendriya Vidyalaya
AF Station, Sulur

OBSERVATION OF FIRE SAFETY AUDIT

1. Reference is made to your letter No F-2-8/KV-S/AFS/2026-27/Loc 48 dt 02 Sep 26.
2. It is intimated that fire safety audit was conducted on 08 Sep 26 at your premises during the issuance of the fire safety certificate. The audit revealed certain observations as under :-
 - 2.1. Installation of one 3 Kg CO2 fire extinguisher is required to Staff room, Principal room, Office room, Senior computer lab, Language Lab, Chemistry Lab, and Biology Lab.
 - 2.2. Installation of fire alarms and smoke detectors with accessories at prominent locations throughout the school premises.
 - 2.3. Display of Fire Safety Operating Procedures (SOPs) and fire evacuation plans at prominent locations to ensure all staff and students are aware of the necessary actions in case of a fire emergency.
3. You are requested to take necessary action for early rectification of ibid observation and completion report may be issued to this section.
4. Accord priority, please.

(Nandni Sorout)
Flt Lt
Depot Fire Offr

FIRE SAFETY CERTIFICATE

File No : 5BRD/1501/5/Org (Fire)

Date : 09 Sep 26

Certified that the **PM SHRI KV AFS, SULUR** (name of the building or premises) at Air Force Station, Sulur, Coimbatore-District, Tamil Nadu-641401 (address) comprised of -- basement(s) and 55 class rooms, 13 Department Labs & 02 Office rooms occupied by Kendriya Vidyalaya Air Force Station, Sulur (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with Air Force Service rules (IAP-4502) and verified by the officers concerned of fire service on 08 Sep 26 (date of inspection) in the presence of Mr Rakesh Kumar Mishra, Principal, KV School (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy upto classes XIIth Std with effect from 09 Sep 26 for a period of one year in accordance with rule and subject to compliance of specific conditions as appended.

1. Qty-01 each 3 Kg CO₂ fire extinguisher is to be required at Staff room, Principal room, Office room, Senior computer lab, Language Lab, Chemistry Lab & Biology Lab.
2. Fire alarm, smoke detector with its accessories are to be required at prominent places.
3. SOP in case of fire and fire evacuation plan are to be required to display at prominent places.

Issued on 09 Sep 26 (date of issue) at KV School, Sulur (place) by * Strike out whichever is not applicable.



Signature with seal :

Name : Nandni Sorout

Designation : Flt Lt

Name and address of Department/Office : 5BRD
Air Force Station Sulur

To

Mr Rakesh Kumar Mishra
Principal, PM Shri KV School
Air Force Station, Sulur
Coimbatore – District
Tamilnadu - 641 401
(Name & Address of the institution)

ENDORSEMENT

The No objection certificate issued by fire service stands cancelled and annulled due to non-compliance regarding the timely refilling of fire extinguishers. (reasons to be recorded).

Place : 5 BRD AFS Sulur

Date : 09 Sep 26

(Nandni Sorout)

Flt Lt

Depot Fire Offr

AFNET: 4324-7228

Fire Section
5BRD, AF

5BRD/1501/5/Org (Fire) dt 09 Sep 26

The Principal
PM Shri Kendriya Vidyalaya
AF Station, Sular

ISSUE OF FIRE SAFETY CERTIFICATE

1. Reference is made to your letter No F-2-8/KV-S/AFS/2026-27/Loc 48 dt 02 Sep 26.
2. Fire safety certificate in respect of KV School is enclosed herewith duly signed by undersigned Offr.
3. For info and necessary action, please




(Nandni Sorout)
Flt Lt
Depot Fire Offr



Enclosure :- As stated