ABC DRY POWDER TYPE FIRE EXTINGUISHER

KEEP THIS END UP WHILE USING

Operating Temperature
(-)30° to (+)60°C
Tested at 35 BAR
Service Pr. 15 BAR

INSPECTION : MONTHLY CHECK THAT THE FIRE EXTINGUISHER IS CHARGED UP TO PRESSURE AGED AND THE SEAL IS INTACT. MAKE SURE THAT THE NOZZLE IS UNOBSTRUCTED. THE GREEN ZONE IS AN INDICATOR OF THE STATE OF READINESS OF THE EXTINGUISHER. IN CASE OF THE INDICATOR SHIFT TO RED ZONE, PLEASE CONTACT THE SUPPLIER OR MANUFACTURER.

MAINTENANCE : CARE AND MAINTENANCE AS PER IS 2190. PERIODICALLY CHECK TO ENSURE THAT THE SAFETY SEAL AND TAMPER INDICATOR ARE NOT MISSING OR BROKEN. CHECK THAT THE EXTINGUISHER IS FULL BY WEIGHING OR LIFTING. ENSURE TO CHECK THE INBUILT PRESSURE GAUGE PERIODICALLY. THE GREEN ZONE IS INDICATOR OF THE STATE OF READINESS OF THE EXTINGUISHER. RECHARGE AFTER ANY USE

RECHARGE : AS THE PRESSURE DROPS, THE NEEDLE WILL SHIFT TO THE RED ZONE. CONTACT MANUFACTURER OR AUTHORIZED SUPPLIER ONLY

Contents: Monu Ammonium Phosphate (MAP)

Megdoot **ABC POWDER**

CAPACITY 9 Kgs.

FIRE RATING : 4A 144B

GROSS WT. : 12.2 KG. ±5%

MFG. YEAR: 2025 S No.: 04186

Manufactured By :

MALHOTRA SAFETY TRADERS

DELHI-95 (INDIA)

Email : kmmalhotrafire@gmail.com