Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. Dated: 5/5/2026

It is certified that an inspection team headed by PANGANGBAM VICTORIA, A.E IE PHE DIVN

(Name of Officers with designation) from Imphal-East PHED

inspected the KENDRIYA VIDYALA AKAMPAT, KHURAI LAMLONG

(Name & Address of the school) on 30/4/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. IEDL/PHED 576/04 dated 5/5/2026 of Imphal East District Lab (PHED Lab) certified that the KENDRIYA VIDYALAYA AKAMPAT (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 5/11/2026

Assistant Engineer
Imphal East P.H.E. Division
PHED, Manipur

Signature with Seal: .....
Name : PANGANGBAM VICTORIA
Designation : A.E, IE PHE DIVN
Name & Address of the Office / Department : PHED, MANIPUR

To
KENDRIYA VIDYALAYA AKAMPAT
KHURAI LAMLONG, BAZAR
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

IMPHAL EAST DISTRICT LABORATORY
PUBLIC HEALTH ENGINEERING DEPARTMENT
GOVERNMENT OF MANIPUR
imphaleast5@gmail.com

IMPHAL EAST DISTRICT LABORATORY ★ PHED, IMPHAL EAST DIVISION ★

FF-13
IEDL/PHED, Manipur
Page No. 1/1

Name & Address of Company & Customer:	TEST REPORT	
Name of School :- KENDRIYA VIDYALAYA AKAMPAT Address:- KHURAI LAMLONG BAZAR	Report No. IEDL/PHED 576/04 Date of Tested : 30-04-2026 Sample ID:576 / 04 Date of Collection of Sample: 30-04-.2026 Date of report: 05-05-.2026	Certificate TC-14534

1	Description of Sample (As declared by customer)	Water
2	Sample Mark (if any, given by the customer)	NA
3	Date of Sampling by the Customer	30-04-2026
4	Source & Place of Sampling	TAP WATER
5	Type of Water	TREATED WATER
6	Sampling Plan &Procedures used	NA
7	Quantity of Water	2 liter in Plastic Jerrican bottle

We hereby certify that the following sample submitted to the laboratory has been analyzed with the following results

Analysis Results (As per IS10500:2012)
Chemical & Bacterogical Testing

Sl. no	Characteristic	Acceptable Limit	Permissible Limit	Method of Test	Results 1	Results 2
1	Chloride (as Cl) in mg/l	250	1000	APHA 24th Edition4500-Cl^- B	32.00	
2	Total Dissolved Solids in mg/l	500	2000	APHA 24th Edition 2540 C	122.00	
3	Total Alkalinity in mg/l as $CaCO_3$	200	600	APHA 24th Edition 2320 B	44.00	
4	Calcium (as Ca) in mg/l	75	200	APHA 24th Edition 3500 – Ca B	16.80	
5	Magnesium (as Mg) in mg/l	30	100	APHA 24th Edition 3500 Mg B	11.18	
6	pH value at 25°C	6.5-8.5	No Relaxation	APHA 24th Edition 4500-H^+B	7.30	
7	Turbidity in N.T. U	1	5	APHA 24th Edition 2130 B	0.60	
8	Total Hardness in mg/l as $CaCO_3$	200	600	APHA 24th Edition 2340 C	88.00	
9	***Bacteroligical**	0	0	H_2S Strip Method	NIL	
10	***Iron (as Fe) in mg/l**	**1.0**	**No Relaxation**	**APHA 24th Edition 3500-Fe B**	0.20	
11	***Fluoride in mg/l as F**	**1.0**	**1.5**	**APHA 24th Edition 4500-F^- D**	0.18	
12	***** **Sulphate (as SO_4) in mg/l**	**200**	**400**	**APHA 24th Edition4500-SO_4^{2-} E**	10.00	
13	***Electrical Conductivity in µmho/l**	-	-	**APHA 24th Edition 2510 B**	188.30	

The results relate only to the item(s) tested.
This Test Report shall not be reproduced except in full, without the permission of IED Laboratory, PHED, Manipur. The reserved part of sample(s) shall be retained for 30days from the date of Completion of Test.
* Mark parameters are not in the scope of NABL
* Sample is safe for Drinking for the above parameters.

Prepared by: - Ok.Nanao Singh
Ok. Nanao Singh
Designation : Jr .chemist

Authorized signatory:
Name: -Salima Begum
Designation: - Executive Engineer
(As Quality Manager)
Imphal East District Lab. PHED, Manipur

Executive Engineer,
Imphal East P.H.E Division
P.H.E.D., Manipur