



सत्यमेव जयते

ಭಾರತಸರ್ಕಾರ
भारतसरकार -
GOVERNMENT OF INDIA

ಕೇಂದ್ರೀಯ ಲೋಕ ನಿರ್ಮಾಣ ವಿಭಾಗ
केन्द्रीयलोकनिर्माण विभाग
CENTRAL PUBLIC WORKS DEPARTMENT



ಸಹಾಯಕ ಇಂಜಿನಿಯರ್ ಕೆಫಬಿ (ಇ)
ಬೆಂಗಳೂರು
ಕೇಂದ್ರವಿದ್ಯುತ್ ಉಪವಿಭಾಗ ಸಂಖ್ಯೆ-III,
8ನೇ ಮಹಡಿ, GPOA,
ಸರ್ವೋನ್ನತ ಶಿಕ್ಷಣ ಕೇಂದ್ರೀಯ ಭವನ,
ದೊಮ್ಮಲೂರು, ಬೆಂಗಳೂರು-560 071

सहायक अभियंता, का कार्यालय (ई)
ಬೆಂಗಳೂರು ಕೇಂದ್ರೀಯ ವಿದ್ಯುತ್ ಉಪ ಮಂಡಲ- 3,
ಆಠವಿ ಮಂಜಿಲ, ಜಿ ಪಿ ಆ ಎ,
ಸರ್ ಎಂ ವಿಶ್ವೇಶ್ವರಯ್ಯ ಕೇಂದ್ರೀಯ ಭವನ,
ಡೊಮ್ಮಲೂರು, ಬೆಂಗಳೂರು 560 - 071

Office of the Assistant Engineer (E),
Bangalore Central Electrical Sub Division No-3,
8th Floor, GPOA,
Sir M Visvesvaraya Kendriya Bhavan,
Domlur, Bangalore - 560 071

Email: aeebcesd3@gmail.com

Ph: 080 - 29902935

Fax: 080 - 22861570

No.23(79)/BCESD-III/2026/436(E)

Date: 30 /07/2026

To,

The Principal,
Kendriya Vidyalaya,
Diesel Loco Shed, Krishnarajapuram,
Bengaluru-560036

Sub: Certification regarding installation of fire-fighting equipment in the school building – reg.
Ref:- Ltr No. 23(79)/BCESD-III/2026/273 (E) Dtd 26.05.2026

Name of work: Construction of "A" Type School Building and 9 Numbers Staff Quarters (4 Numbers Type II, 4 Numbers Type - III and 1 Number Type - V Quarters) including Internal Water Supply, Sanitary Installations, IEI works, Water supply pump sets, LT distribution, Street lighting and Sports lighting, Firefighting with First Aid Hose Reel system etc. and Development of sites & Bulk Services (Roads, Compound wall, Drains, Paver blocks etc.) for Kendriya Vidyalaya at KR Puram, Bangalore, Karnataka in EPC mode (Design and Build Basis).

Agreement No: 02/CE/EE-Bangalore-2023-24.

Sir,

It is hereby certified that the fire-fighting installations provided under the work, including fire-fighting pump sets, first-aid hose reels and fire extinguishers, have been installed at the designated locations in the school building are functional.

The detailed list of the installed fire-fighting equipment is enclosed herewith for reference. The handing-over notes in respect of the completed installations were also forwarded to your office vide letter 23(79)/BCESD-III/2026/273 (E) dtd 26.05.2026

S.No	Description of Item	Location	Qty	Unit	Total
	School Building				
1	450 LPM 7.5 HP Motor Pumpset	Terrace	2	Each	02
2	First Aid HoseReel	Ground Floor	2	Each	06
		First Floor	2	Each	
		Second Floor	2	Each	

S.No	Description of Item	Location	Qty	Unit	Total
3	CO2 Fire Extinguishers	Ground Floor	1	Each	03
		First Floor	1	Each	
		Second Floor	1	Each	
4	ABC Fire Extinguishers	Ground Floor	4	Each	12
		First Floor	4	Each	
		Second Floor	4	Each	

This is for your information and necessary action please.


Assistant Engineer (E),
BCESD-III, CPWD, Bangalore

Copy to: 1. The Executive Engineer (E), BCED-I, CPWD, Bangalore for information please.


Assistant Engineer (E),
BCESD-III, CPWD, Bangalore