

GOVT. OF ARUNACHAL PRADESH
OFFICE OF THE ASSISTANT ENGINEER
PHE & WS SUB -DIVISION
KARSINGSA

No .AEK/PHESD/Lab-1/2012-13/ 63.

Dtd.04/01/21

To,

The Principal
Kendriya Vidyalaya Kimin
Arunachal Pradesh

Sub:- Issuance of water safety Certificate (Portable Drinking Water) of
Kendriya Vidyalaya Kimin

Ref: F 1478/112/KVK/2020-21 Dated 17th Dec 2020


Sir,

With reference to your letter and subject cited above, Enclosed please find herewith submission of water testing report of Kendriya Vidyalaya Kimin. It may be noted that the test report of portable drinking water sample of the institute is within permission limit and safe to be consumed.

This is for your information and kind perusal please.


Enclosed:- As state above.


Yours faithfully,


Assistant Engineer,
PHE & WS Sub-Divisi
Karsinga.

WATER QUALITY TESTING REPORT OF KENDRIYA VIDYALAYA KEMIN
 PERMISISSIUN UJIAN (SMDW/DK/SPI)

S/N	BLOCK	NAME	Iron (0 - 10) mg/l	Nitrates (0 - 20) mg/l	Fluoride (0 - 1.5) mg/l	Chlorine (0 - 250) mg/l	Residual chlorine (0 - 5) mg/l	pH(6.8 - 8.4)	Alkalinity γ (0 - 500) mg/l	Nitrite (0 - 1.6) mg/l	Turbidity	Total Hardness (0 - 500) mg/l	Bacterial	Remarks
1	KIMIN	Kendriya Vidyalaya	0.75mg/l	0.067mg/l	0.0mg/l	17.3mg/l	0.09mg/l	6.8	70mg/l	0.004mg/l	5.0 NTU	30mg/l	Nil	safe


 Laboratory Assistant,
 PHE & WS Sub-Division
 Karantina


 Assistant Engineer,
 PHE & WS Sub-Division
 Karantina


 Junior Engineer
 PHE & WS Sub-Division
 Kimin Dirde