



ITANAGAR

No.DIR/F&ES/FPW-14 (E)/KVK/2020

Dated Itanagar, the 16th July 2024


// PROVISIONAL FIRE SAFETY CERTIFICATE //

Certified that "Kendriya Vidyalaya Kimin", 10th ITBP Force, Kimin, District Papumpare, Arunachal Pradesh was inspected by the Inspecting Officer, Fire Station, Naharlagun on 16/07/2024 and report submitted thereafter to this office and found that the said Institution have deemed complied with the fire safety requirements for Educational Institution as on date. The provisional Fire Safety Certificate is valid for a period of 1 (one) year only from the date of issue.

This has the approval of Director, Fire & Emergency Services, Arunachal Pradesh.

Condition for the validity of Provisional Fire Safety Certificate under:-

1. All Fire Protection Requirements Installed as per Educational Occupancy, Zone-I, Group-B (I) as specified in Annexure-B-I read with Chapter – 11 of APBBL-2019 must be in working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate should not be treated in any case for regularizations of unauthorized construction/ unauthorized use of land, if any.
6. The owner/occupier shall apply for renewal of this certificate on two months prior to its expiry as per clause 11.3 of APBBL-2019 alongwith a copy of this Certificate.



(S. Chakraborty) APPS


Assistant Director
Fire & Emergency Services
A.P., Itanagar

Dated Itanagar, the 16th July 2024

No.DIR/F&ES/FPW-14 (E)/KVK/2020

Copy to:

1. The Principal, Kendriya Vidyalaya Kimin, 10th ITBP Force, Kimin, District Papumpare, Arunachal Pradesh for information.
2. Office Copy.


Assistant Director
Fire & Emergency Services
A.P., Itanagar