



afes@ahmedabadcity.gov.in



FORM B 13.3

## FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/CFOAMC/2021/00015224

Date: 01/04/2025

FSC Safety Certificate Renewal (FSCR) No. FSCA/O/CFOAMC/2021/00015224/R1

Building Occupancy/Category: Educational (non-residential)

To,

SECURE fire and safety Services

KENDRIYA VIDYALAYA SABARMATI NEW RAILWAY COLONY D CABIN SABARMATI NEW RAILWAY COLONY D CABIN

SABARMATI AHMEDABAD Ahmedabad MC 380019

Fire Region: Ahmedabad MC

Mobile No: 9375223999 Email ID: securefireservice@gmail.com

This has reference to your Application No. 2025/00114501 dated 25/03/2025 for Fire Safety Certificate Renewal (FSCR) for the building/premise KENDRIYA VIDYALAYA SABARMATI (name of the Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number:
4. Village Name: AHMEDABAD
5. Name of Block(s): 1

The building/premise was inspected on 01/04/2025 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 01/04/2025
2. Six monthly inspection was done on 01/04/2025

The Fire Safety Certificate is renewed for a period of **two (2)** years upto **01/04/2027** in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



### Digitally Verified

Digitally verified by: Jagdish Solanki  
Fire Safety Officer - General (FSO-G)  
2021/000518

Date: 01/04/2025  
Time: 07:40 PM



FSCA/O/CFOAMC/2021/00015224/R1

*This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at [www.gujfiresafetypcop.in](http://www.gujfiresafetypcop.in).*

*Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.*