No.12/FSR/DFO(F.P)/HFS/MY/2026-27

Office of the District Fire Officer
Fire Prevention & Protection
Karnataka Fire and Emergency Services
Hebbal Fire Station, Mysuru-570 016
Date: 13-01-2026.

To,
The Principal,
Kendriya Vidyalaya, School
BRBNMPL, Mysuru-03

Sir,

Sub : Issue of *" Fire safety recommendation"* to Exiting M/s Kendriya Vidyalaya School BRBNMPL, Mysuru-570003
Ref:1.Application Date:- 27-11-2025
2.Report No. 93(02)/FSR/FSO/HFS/MYS/2025 dated:-08-12-2025

><◇◇*@*◇◇<

With reference to the subject above cited, the premises of **M/s Kendriya Vidyalaya School BRBNMPL, Mysuru-570003** was inspected by, Fire Station Officer, Hebbal Fire Station, Mysuru on 01-12-2025 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under.

ANNEXURE-1
Group B Educational Buildings
NBC-2016, Part-4, Table 7 (2) 3.1.3 Group B Educational Buildings
Sub Division B1 & B2
(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

Part-A. Details of the building / premises:-

01	Name and Address of the Applicant.	:	The Principal, Kendriya Vidyalaya, School BRBNMPL, Mysore-03
02	Name and Address of the premises.	:	Kendriya Vidyalaya, School BRBNMPL, Mysore-03
03	Name and address of the Building owner		The Principal, Kendriya Vidyalaya, School BRBNMPL, Mysore-03
04	Number of buildings	:	One educational building.
05	Number of floors	:	Ground floor & 01 Upper floor only.
06	**Floor-wise details of occupancy:-**		

DISTRICT FIRE OFFICER FIRE PREVENTION & PROTECTION HEBBAL MYSURU KARNATAKA FIRE & EMERGENCY SERVICES

		:	**Ground Floor**:- 07 class rooms & First aid room. **First Floor** :- 07 class rooms, 02 Labs & First aid room.
07	Height of the building	:	07.90 mtrs.
08	Site area	:	20,234.00 Sq.mtrs.
09.	Built-up area of each floor:-		Ground Floor:- 865.00 sq. mtrs. First Floor :- 865.00 sq. mtrs.
10.	**Total built-up area**	:	1730.00 Sq.mtrs .
11.	Surrounding properties:-		
	West (Front)	:	12.00 mtrs wide road.
	East (Rear)	:	09.00 mtrs wide internal road.
	North (Side)	:	Open ground
	South (Side)	:	Open ground
12.	**Set-back area available around the building :-**		
	West (Rear)	:	Min. 05.00 mtrs.
	East (Front)	:	Min. 10.00 mtrs
	North (Side)	:	Open ground
	South (Side)	:	Open ground

Part-B. On inspection of this School premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)
1.	Accessibility	The premise is accessible from 09.00 mtrs wide internal road located on eastern side. This road is hardened to carry weight of 45,000kgs.	Adequate.
2.	Number of entrances	01 Entrance of 05.00 mtrs. width has been provided.	Adequate.
3.	Diesel generators	Not provided.	Diesel generator of 15 KVA capacity should be provided to supply alternative power supply.
4.	No. lifts and capacity no of Persons	No of lifts : -- Capacity of lifts : --	----
5.	Number of staircases	Number of the 02	Adequate.

DISTRICT FIRE OFFICER ★ FIRE PREVENTION & PROTECTION ★ KARNATAKA FIRE & EMERGENCY SERVICE HEBBAL MYSORE-16

	available	staircases		
		Width of staircases	01.50 mtrs.	
		Width of treads	30 cms.	
		Higtht of risers	15 cms.	
		No.of risers per flight	10 nos.	
		Height of handrails	01.00 mtrs.	
		Head room clearence	02.50 mtrs.	
6.	Portable Fire extinguishers	Provided : 1) 08 Nos CO2 Type fire extinguisher of 4.5Kgs capacity 2) 05 Nos ABC type extinguisher of 6kgs capacity		A. One Water mist extinguisher of 9 liters capacity should be kept near each staircase landing. B. One Mechanical foam extinguisher of 9 liters capacity & One ABC type extinguisher of 6Kgs capacity should be provided near Diesel Generator.
7.	First aid hose reel hose	Not provided.		Recommended to provide Hose reel hose of 19mm size and of 30.00 mtrs. length with drum and shut off branch having a nozzle of 5 mm size shall be provided near the staircase landing at each floor (1no hose reel hose system should be provided for every 1000.00 Sq.mtrs of built up area). The hose reel hose of each floor shall be connected.
8.	Terrace tank over respective tower terrace	Provided 2,000 ltrs.		Provided 10,000 ltrs capacity water tank. **(The water tank should be kept exclusively for firefighting purpose)**
9.	At the terrace tank level with minimum pressure of 3.5 kg/cm^2	Not Provided		Recommended to provide 01 no Booster Pump near over head tank capable of delivering 450 lpm.
10.	Escape routes	Not Provided		directions in which the Publics have to move in the event of any emergency have been indicated in the corridor

DISTRICT FIRE OFFICER ★ KARNATAKA FIRE & EMERGENCY SERVICE ★ FIRE PREVENTION & PROTECTION HEBBAL MYSORE-16

			on each floor during evacuation. It should written in luminous paint
11.	Fire order (Fire Safety plans)	Not displayed.	Provided A notice board indicating the action should be taken by the employees in case of any emergency is displayed with the telephone number of **RBI Fire Station 0821-2582103** & Control room 101/112 and the nearest Ambulance service and Police Station.
12.	No smoking board.	Not displayed.	COTPA Sec-4, direction NO Smoking area smoking here is an offence board should be written in English & Kannada both language shall be prominently displayed at inside the entry / exit of the each floor.
13.	Fire Siren	Not Provided	Recommended to provide A Fire Siren shall be installed in the premises to inform the inmates in case of fire emergency and evacuate the area.
14.	Nominate one Fire Nodal Officer	--	A Fire Nodal Officer shall be nominate either from teaching or non teaching staff.
15.	Fire Fighting training	Total 02 No's employees got a training in fire prevention, fire fighting and evacuation measures from 11-11-2024 to 12-11-2024 at Regional Training Centre, Hebbal fire station premises, Mysuru	Complied.
16.	***Fire precautionary measures :-***		

DISTRICT FIRE OFFICER ★ FIRE PREVENTION & PROTECTION HEBBAL MYSORE-16 ★ KARNATAKA FIRE & EMERGENCY SERVICES

room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.

B) Accumulation of combustible waste in and the premises should be avoided.

C) The exit ways shall be always kept clear without any obstruction.

D) Liquefied petroleum gas should not be stores in the building.

E) The doors shall not be kept locked / latched during working hours and shall be free from obstruction.

F) During the class hours the class room doors shall not be locked from inside to outside.

G) As per Honorable Supreme Court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year be conducting Fire Safety drills with co-ordinate Fire Service department.

Under the above circumstance, the Karnataka Fire & Emergency Services Department is issuing "***Fire Safety Recommendation***" of **M/s Kendriya Vidyalaya School BRBNMPL, Mysuru-570003** subject to condition and compliance of the above recommendations in Column-4 of serial-B within 3 months and compliance to the undersigned.

"***This Fire Safety Recommendation is valid for Only One Year from the date of issued and it is renewable".***

All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.3 of Fire and Life safety will have to be complied with mandatorily.

Yours faithfully.

13/01/21

District Fire Officer
Fire Prevention & Protection
Hebbal Fire Station
Mysore - 570 016

Copy to, with due respect
DGP & DG
Karnataka Fire and Emergency Services,
Banglaore-42.

Copy to,
Fire Station Officer,
Hebbal fire station, Mysuru.