

Office of the Executive Engineer, Public Works Department, Division, Opp. Old Govt. Hospital, Chickballapur-562 101.	ಕಾರ್ಯಪಾಲಕ ಇಂಜಿನಿಯರ್ ರವರ ಕಛೇರಿ ಲೋಕೋಪಯೋಗಿ ಇಲಾಖೆ, ವಿಭಾಗ, ಪಳೇ ಸರ್ಕಾರಿ ಆಸ್ಪತ್ರೆ ಎದುರು, ಚಿಕ್ಕಬಳ್ಳಾಪುರ-562 101.
E-mail: cecbp@kpwd.gov.in / cecbp.kpwd@gmail.com	Phone/Fax No: ದೂರವಾಣಿ/ಫ್ಯಾಕ್ಸ್ ಸಂಖ್ಯೆ: 08156-274415

ಸಂಖ್ಯೆ: ಕಾಪಾಇಂ/ಲೋಇ-ವಿ/ಚಿಬಪುರ/ತಾತಾ/ಸಇಂ-1/ತಾ.ದ್ಯ.ಪತ್ರ/2022-23 / 272 ದಿನಾಂಕ: 09/05/2022

ರವರಿಗೆ,

ಪ್ರಾಂಶುಪಾಲರು,
ಕೇಂದ್ರೀಯ ವಿದ್ಯಾಲಯ,
ಗೌರಿಬಿದನೂರು ತಾಲ್ಲೂಕು,
ಚಿಕ್ಕಬಳ್ಳಾಪುರ ಜಿಲ್ಲೆ.

ಮಾನ್ಯರೆ,

ವಿಷಯ: ಕೇಂದ್ರೀಯ ವಿದ್ಯಾಲಯ, ಗೌರಿಬಿದನೂರು, ಗೌರಿಬಿದನೂರು ತಾಲ್ಲೂಕು, ಚಿಕ್ಕಬಳ್ಳಾಪುರ ಜಿಲ್ಲೆ ಕಟ್ಟಡದ ಸುರಕ್ಷತಾ ಪ್ರಮಾಣ ಪತ್ರ ನೀಡುವ ಬಗ್ಗೆ.

- ಉಲ್ಲೇಖ: 1) ಸರ್ಕಾರದ ಸುತ್ತೋಲೆ ಸಂಖ್ಯೆ: ಲೋಇ 59 ಬಿಇಡಿ 2019 ದಿ: 29-10-2020
2) ಸರ್ಕಾರದ ನಡವಳಿ ಸಂ:ಇಪಿ 46 ಎಸ್‌ಹೆಚ್‌ಹೆಚ್ 2020 ದಿ: 12-10-2020
3) ತಮ್ಮ ಮನವಿ ಪತ್ರದಂತೆ 06-05-2022
4) ಸರ್ಕಾರದ ಪತ್ರದ ಸಂಖ್ಯೆ: ಲೋಇ/59/ಬಿಇಡಿ/2019 ದಿನಾಂಕ: 26-02-2021
5) ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಇಂಜಿನಿಯರ್, ಲೋ.ಇ. ಉಪ-ವಿಭಾಗ, ಗೌರಿಬಿದನೂರು ರವರ ಪತ್ರದ ಸಂಖ್ಯೆ:48/2022-23 ದಿನಾಂಕ:07-05-2022



ಮೇಲ್ಕಂಡ ವಿಷಯಕ್ಕೆ ಸಂಬಂಧಿಸಿದಂತೆ, ಕೇಂದ್ರೀಯ ವಿದ್ಯಾಲಯ, ಗೌರಿಬಿದನೂರು ತಾಲ್ಲೂಕು ರವರ ಕಟ್ಟಡದ ಸುರಕ್ಷತಾ ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ನೀಡಲು ಉಲ್ಲೇಖ ಪತ್ರ (5) ರಲ್ಲಿ ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಇಂಜಿನಿಯರ್, ಲೋ.ಇ. ಉಪ ವಿಭಾಗ, ಗೌರಿಬಿದನೂರು ರವರು ದಿನಾಂಕ:16-04-2022 ರಂದು ತಮ್ಮ ಸಂಸ್ಥೆಯ ಕಟ್ಟಡವನ್ನು ಜಂಟಿ ಪರಿವೀಕ್ಷಣೆ ಮಾಡಿ ಈ ಕೆಳಗಿನಂತೆ ವರದಿ ಮಾಡಿರುತ್ತಾರೆ.

ಕಟ್ಟಡವು ನೆಲ ಮತ್ತು ಮೊದಲನೇ ಅಂತಸ್ತುಗಳನ್ನು ಒಳಗೊಂಡಿದ್ದು, ಕಟ್ಟಡವು ಗೌರಿಬಿದನೂರು ನಗರಸಭೆ ವ್ಯಾಪ್ತಿಗೆ ಒಳಪಟ್ಟಿದ್ದು, ಕಟ್ಟಡದ ಪರಿವೀಕ್ಷಣೆ ಸಮಯದಲ್ಲಿ ಈ ಕೆಳಕಂಡ ಅಂಶಗಳನ್ನು ಗಮನಿಸಲಾಗಿರುತ್ತದೆಂದು ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಇಂಜಿನಿಯರ್‌ರವರು ವರದಿ ಮಾಡಿರುತ್ತಾರೆ.

Criteria	NBC Standards	Actual Observation	Remarks (Satisfactory/ Not Satisfactory)
1) Minimum Distance from Electrical Line	(A) For < 650 volts line i) 1.20m Horizontal distance ii) 2.50m Vertical distance (B) For > 650 volts line (Ref Page 138, NBC 2016)	No Electrical Lines observed around the School Building	Satisfactory
2) Ceiling Height	For Educational Building \geq 3.60m	Ground Floor = 3.00m First Floor = 3.00m	Satisfactory
3) Minimum clear width of staircase, corridor, exit doorways, ramps	Width per Person (users) Stairways = 10mm/Person Ramp = 6.50mm/Person Minimum widths Stairs = \geq 1.50m, Tread = 0.30m, Riser = 0.15m	Staircase width = 1.50m, Tread = 0.30m, Riser = 0.15m	Satisfactory

Criteria	NBC Standards	Actual Observation	Remarks (Satisfactory/ Not Satisfactory)
4) Emergency vehicle Access requirement	Around building minimum 6.00m	Provided	Satisfactory
5) Bathroom & WC requirement	WC = 1.10 Sqm	Ground Floor WC = 1.10 Sqm First Floor WC = 1.10 Sqm	Satisfactory
6) Ramp gradient requirement	Maximum gradient = 1:10	Provided	Satisfactory
7) Separate Toilet for Differently abled persons	Each floor minimum 1 toilet	provided	Satisfactory
8) Ramp/ Lift for Differently abled persons	Should be provided above Ground Floor	provided	Satisfactory

Note: Above criteria's are considered in view of minimum safety of schoolchildren (Neglecting elders and persons with disabilities) for temporary permission of school building only.


ಕಟ್ಟಡದ ಸುರಕ್ಷತೆಗೆ ಸಂಬಂಧಿಸಿದಂತೆ, ಕಟ್ಟಡದ ಸದೃಢತೆಯ ಬಗ್ಗೆ ದಿನಾಂಕ:13-04-2022 ರಂದು M/s. Karnataka Material Test House Pvt., Ltd, No.-8(10/3), 4th cross Basaveshwara layout, Nagashettihalli, RMV 2nd stage Bangalore-560094 (REPORT NO.KMTH/NDT/325/2022-23) Concrete Non Destructive Test (NDT) ಮುಖಾಂತರ ಪರೀಕ್ಷೆಗಳನ್ನು ಕೈಗೊಂಡು ಕಟ್ಟಡ ಸದೃಢತೆಯಿಂದ ಇರುವುದು ಕಂಡು ಬಂದಿರುತ್ತದೆ ಎಂದು ವರದಿ ಮಾಡಿರುತ್ತಾರೆ. ಸದರಿ ಕಟ್ಟಡವು ಆರ್.ಸಿ.ಸಿ. ಕಾಲಮ್ಸ್, ಬೀಮ್ಸ್ ಮತ್ತು ರೂಫ್‌ಅನ್ನು ಒಳಗೊಂಡಿದ್ದು, ಕಟ್ಟಡವು ಶಾಲಾ ಸಂಸ್ಥೆಯವರು ನೀಡಿರುವ ನಕ್ಷೆಯಂತೆ ನಿರ್ಮಿಸಿರುವುದನ್ನು ಗಮನಿಸಲಾಗಿರುತ್ತದೆ ಹಾಗೂ ಸದರಿ ಕಟ್ಟಡವು Structurally Stable ಇರುವುದಾಗಿ ಪರಿಗಣಿಸಿ ನಿರೀಕ್ಷಿಸಿ ಪತ್ರವನ್ನು ನೀಡಲು ಉಲ್ಲೇಖ ಪತ್ರ (5) ರಲ್ಲಿ ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಇಂಜಿನಿಯರ್, ಲೋ.ಇ. ಉಪ-ವಿಭಾಗ, ಗೌರಿಬಿದನೂರುರವರ ವರದಿಯಲ್ಲಿ ಸೂಚಿಸಿರುತ್ತಾರೆ. ಅದರಂತೆ ಕಟ್ಟಡದ ಸುರಕ್ಷತೆ ಬಗ್ಗೆ ನಿರಪೇಕ್ಷಣಾ ಪತ್ರ ನೀಡಲಾಗಿದೆ.

ತಮ್ಮ ವಿಶ್ವಾಸಿ,

ಸಹಿ/-

ಕಾರ್ಯಪಾಲಕ ಇಂಜಿನಿಯರ್,
ಲೋ.ಇ., ಚಿಕ್ಕಬಳ್ಳಾಪುರ ವಿಭಾಗ,
ಚಿಕ್ಕಬಳ್ಳಾಪುರ.

- ✓ 1. ಪ್ರತಿಯನ್ನು ಉಪ ನಿರ್ದೇಶಕರು, ಸಾರ್ವಜನಿಕ ಶಿಕ್ಷಣ ಇಲಾಖೆ, ಚಿಕ್ಕಬಳ್ಳಾಪುರ ಜಿಲ್ಲೆ, ಚಿಕ್ಕಬಳ್ಳಾಪುರರವರ ಮಾಹಿತಿಗಾಗಿ ಸಲ್ಲಿಸಲಾಗಿದೆ.
2. ಪ್ರತಿಯನ್ನು ಸಹಾಯಕ ಕಾರ್ಯಪಾಲಕ ಇಂಜಿನಿಯರ್, ಲೋ.ಇ., ಉಪ-ವಿಭಾಗ, ಗೌರಿಬಿದನೂರುರವರ ಮಾಹಿತಿಗಾಗಿ ರವಾನಿಸಿದೆ.
3. ಕಛೇರಿ ಪ್ರತಿ.


ಕಾರ್ಯಪಾಲಕ ಇಂಜಿನಿಯರ್,
ಲೋ.ಇ., ಚಿಕ್ಕಬಳ್ಳಾಪುರ ವಿಭಾಗ,
ಚಿಕ್ಕಬಳ್ಳಾಪುರ.





केन्द्रीय माध्यमिक शिक्षा बोर्ड
Central Board of Secondary Education
संबद्धता - School Affiliation Re-engineered Automation System 2.0 (SARAS
2.0)



Letter Details

Dated: 14/10/2022

NO : CBSE/800152/SL-00171-2324/2023-24

The Manager,
KENDRIYA VIDYALAYA GAURIBIDANUR
SERICULTURE OFFICE BUILDING, NEAR NETAJI STADIUM, GAURIBIDANUR
KARNATAKA ,CHIKKABALLAPUR, 561208
(M: 08155295015)

SUBJECT: -FRESH AFFILIATION UP TO SECONDARY LEVEL-regarding.

Ref : Application No.:- SL-00171-2324 Dated:06/06/2022

Sir/Madam,

This is with reference to school application on the subject cited above. I am directed to convey approval of the Board for Fresh Affiliation Up to Secondary Level as per details given below :

Affiliation No used as User ID for both OASIS and LOC/Registration System	800152
School No	49202
Password for OASIS and LOC/Registration Systems is same as that used for Affiliation Application.	
Affiliated for	Secondary School Examination Class 1 to 10
Category	Fresh Affiliation
Period of affiliation	01.04.2022 to 31.03.2027
Year and Month From which admission can be taken in Class-IX	1 April,2022
Year and Month in which first batch of Class-X will appear in board examinations	1 April,2024

The above is subject to fulfillment of the following conditions:-

1. The approval is based upon the documents /data/information uploaded by the school online. The school will be responsible for its genuineness. In case of any discrepancies, necessary action will be initiated against the school as per Affiliation Bye -Laws-2018.
2. The school will follow the RTE Act, 2009 and instructions issued thereon by the CBSE/Respective State /UT Govt. from time to time. The school will also abide by the conditions prescribed, if any, by the State Government concerned.
3. The School is required to apply on online for extension of affiliation along with the requisite fee and other documents as per Rule 10.3 of Affiliation Bye Laws.
4. The school should go through the provision of Affiliation and Examination Bye Laws and subsequent amendment therein as well as circulars and guidelines /instructions issued by the Board time to time and keep a copy there of for reference purpose and is also advised to regularly visit CBSE websites i.e., <http://cbseacademic.nic.in/> & <http://cbse.nic.in/> for updates.
5. The school to renew mandatory certificates from time to time.
6. The school shall be solely responsible for any legal consequences arising out of the use of school name/logo/society/trust or any other identity /activity related to running of school affiliated to CBSE. All legal expenses incurred by the Board, if any, arising out of these circumstances, shall be borne by the school.
7. Concerned Regional Office is requested to create new email id of school as per direction issued by controller of examination. This E Mail ID is used for communication with CBSE only.
"The school shall possess valid fire safety certificate and Building safety certificate during functioning of the school which shall be renewed from time to time as per norms".

ENROLMENT TABLE

SN	Location of School	Campus area	Affiliation Allowed	Optimum No. of Sections (From classes I/VI to X/XII)
A	Areas/Cities mentioned in clause 3.6	1600 sqm	Up to Class-X only	10
B	Areas/Cities mentioned in clause 3.6	2400 sqm	Up to Class-XII	24
C	Areas/Cities mentioned in clause 3.6	3200 sqm	Up to Class-XII	28
D	Class-X Cities (Clauses 3.5) and Areas mentioned in clause 3.7	2000 sqm	Up to Class-X only	10
E	Class-X Cities (Clauses 3.5) and Areas mentioned in clause 3.7	3000 sqm	Up to Class-XII	24
F	Class-X Cities (Clause 3.5) and Areas mentioned in clause 3.7 and Areas/Cities mentioned in clause 3.4	4000 sqm	Up to Class-XII	28
G	Pan India (Clause 3.3)	6000 sqm	Up to Class-XII	38
H	Pan India (Clause 3.2)	8000 sqm	Up to Class-XII	48
I	Pan India (Clause 3.2)	>8000 sqm	Up to Class-XII The number of sections shall be restricted in accordance with 'H' above with land requirement unit scaled down to 2000 square meters i.e. 12 sections for every 2000 square meter additional land.	
The total number of sections taken together for classes XI and XII should not be more than 1/3 of optimum number of section allowed on the basis of land holding for any school.				
The number of sections and students shall be restricted as per the actual facilities in the school.				
For class rooms of size less than 500 sq feet the enrolment shall be 0.08 X size of class rooms in sq feet				

Important Notes : 1. The school is required to appoint qualified PETs/PTI as per norms. 2. The school is required upload Mandatory Public Disclosure as per Appendix-IX of Affiliation Manual on its website. 3. The school shall inform the Board as and when school will be shifted to its permanent site shall apply in the SARAS Portal for shifting of site. 4. The school is required to arrange/maintain well equipped Labs., enriched Library, clean toilets, playground, Staff Rooms and other infrastructure as per specifications mentioned in the Affiliation Bye-Laws, 2018. 5. The number of sections in the school are restricted to 07 sections as per the availability of classrooms. For classroom size between 400 to 500 Sq. feet, the students shall be restricted to 32 candidates per section and sections shall not be increased without prior approval of the Board. Further, the School is directed not to use classrooms size below 400 Sq. feet

This is an electronically generated document. It does not need any signature.

*To verify the authenticity of the document, please visit (<http://www.saras.cbse.gov.in/saras/AffiliatedList/ListOfSchdirReport>
(<http://www.saras.cbse.gov.in/saras/AffiliatedList/ListOfSchdirReport>)).*

PRINT



Office of the Regional Fire Officer, Bengaluru North Range,
Karnataka Fire & Emergency Services,
Hebbal Fire Station Premises, Manyata Embassy Business
Park, Nagawara Ring Road, Bengaluru-560 045.



No. 25/RFO/BNR/FSR/2022

Dated: 11-04-2022.

ANNEXURE – B
Group - B Educational Building

To,
The Principal,
Kendriya Vidyalaya,
Sericulture Office building,
Near Netaji Stadium,
Gauribidanur Taluk,
Chikkaballapur District – 561 208.

Sir,

Sub : Issue of "Fire safety recommendation" with respect to fire prevention, fire fighting and evacuation measures required at "Kendriya Vidyalaya" at Sericulture Office building, Near Netaji Stadium, Gauribidanur Taluk, Chikkaballapur District – 561 208.

Ref : Your request letter dated: 14-03-2022.

<<<>>>

With reference to the subject cited above, the premises of "Kendriya Vidyalaya" at Sericulture Office building, Near Netaji Stadium, Gauribidanur Taluk, Chikkaballapur District – 561 208 was inspected by me on 06-04-2022 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises. The details are as under:-

Part-A. Details of the building / premises :-

01	Name and Address of the Applicant.	:	<i>The Principal,</i> Kendriya Vidyalaya, Sericulture Office building, Near Netaji Stadium, Gauribidanur Taluk, Chikkaballapur District – 561 208.
02	Name and Address of the premises.	:	Kendriya Vidyalaya, Sericulture Office building, Near Netaji Stadium, Gauribidanur Taluk, Chikkaballapur District – 561 208.
03	Name and address of the Building owner	:	Sericulture Department, Near Netaji Stadium, Gauribidanur Taluk, Chikkaballapur District – 561 208.

8

04	Number of buildings	:	One building.
05	Number of floors	:	Ground & 1 st floor.
06	<u>Floor-wise details of occupancy</u>		
	Ground floor	:	09 Class rooms, 1 Principal office, 1 Office room, 1 Staff room & 1 Store room.
	1 st floor	:	1 Music room, 1 Store room, 1 Computer lab & 5 rooms belongs to Sericulture department.
07	Height of the building	:	7.80 Mtrs.
08	Site area	:	02 Acres.
09.	<u>Built-up area of each floor</u>		
	Ground floor	:	502.79 Sq. Mtrs.
	1 st floor	:	502.79 Sq. Mtrs.
10.	Total built-up area	:	1005.58 Sq. Mtrs.
11.	<u>Surrounding properties:-</u>		
	East (front)	:	9.00 Mtrs. Stadium road.
	West (rear)	:	Private property.
	North (side)	:	Government property.
	South (side)	:	Government property.
12.	<u>Set-back area available around the</u>		
	East (front)	:	Minimum 08.00 Mtrs.
	West (rear)	:	Minimum 01.00 Mtrs
	North (side)	:	Minimum 5.50 Mtrs.
	South (side)	:	Minimum 08.00 Mtrs.
	Allowed setbacks (open space) should be maintained free from further obstructions / constructions.		

Part-B. On inspection of this School/college premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)
01.	Accessibility to the Premises	The premises accessible from 9.00 Mtrs. Stadium road located on the eastern side & it is hardened to carry the Weight of 45,000 Kgs.	Adequate

S

02.	No. of entrances	Provided one entry/exit of 4.50 Mtrs. width from 9.00 Mtrs. Stadium road located on the eastern side.	One more entrance of 4.50 Mtrs. width shall be provided.	
03.	No. of staircases/ lifts available	Nos. of staircases	: 01	1.50 Mtrs. width one more staircase shall be provided.
		Width of staircases	: 1.40 Mtrs.	
		Width of treads	: 30 cms.	
		Height of risers	: 15 cms.	
		Nos. of riser per flight	: 15 risers per flight	
		Height of handrails	: 0.90 Mtr.	
		Head room clearance	: 2.30 mtrs	
04.	Fire extinguisher	<p>Ground floor: 03 nos ABC fire extinguishers each of 05 Kgs capacity have been provided.</p> <p>1st floor: 03 nos ABC fire extinguishers each of 05 Kgs capacity have been provided.</p>	<p>The following extinguishers, should be provided in all the Blocks.</p> <p>A) One water mist extinguisher of 9 ltrs capacity should be kept near each staircase landing.</p> <p>B) One mechanical foam extinguisher of 9 ltrs capacity & one ABC type extinguisher of 6 kgs capacity should be provided near diesel generator.</p> <p>C) One CO₂ extinguisher of 4.5 kgs capacity should be provided near each electrical panel board & electrical room.</p> <p>D) One ABC type extinguisher of 6 kgs capacity should be located as to be available within 15 mtrs radius.</p>	



05.	Diesel generators.	Not provided	Diesel generator of 15 KVA capacity should be provided to supply alternate source of power supply for emergency provisions in the building.
06.	First aid Hose reel hose.	Not Provided.	One Hose reel hose systems near the staircase landing should be provided. (one hose reel system should be provided for every 1,000 Sq.Mtrs. on each floor). Hose pipe of 100 mm dia GI 'C' class pipe & Hose reel hose of 19 mm size and of adequate length to reach the farthest point of the floor should be provided with shut off branch having a nozzle of 5 mm size. The hose reel hose should be connected at each floor landing.
07.	Terrace tank over respective tower terrace.	Not Provided.	<p>Hose reel hose systems should be connected to an overhead tank of 5,000 liters capacity.</p> <p>Note: If the existing building is not capable of sustaining the weight of 5,000 litres tank capacity, provision shall be made to provide water tank on the side of the building with support from the ground level by providing RCC column structure or MS column structure.</p> <p>If there is no options to provide even the above mentioned overhead tank provision shall be made to provide underground water tank of capacity with submersible pump of 5-7 HP capacity.</p>

S

5 KVA
vided to
of

08.	At the terrace tank level with minimum pressure of 3.5 kg/cm ² .	Not Provided.	Hose reel hose system should be connected to a Booster pump capable of delivering 450 litres of water per minute. Further the systems should be connected to an alternative source of power supply.
09.	Automatic sprinkler system	Not provided	Not required
10.	Escape routes	Not marked	Directions in which the Teachers/Staff/Students have to move in the event of any emergency should be displayed in the corridor on each floor during evacuation in each building.
11.	Fire order (fire safety plans)	Not displayed	A notice board indicating the action to be taken by the school staffs/employees in Case of an emergency should be displayed along with Telephone Numbers of Gowribidnaur Fire Station i.e. 08155 - 284101 & 101, and telephone numbers of nearest Ambulance Service & Police station.
12.	No smoking board.	Not displayed.	COPTA Sec-4, direction "No Smoking area smoking here is an offence" board should be written in English & Kannada both languages shall be prominently displayed at inside the entry/exit of each floor.
13.	Fire Siren	Not installed	A fire Siren shall be installed in the premises to inform the inmates in case of fire emergency & evacuate the area.

8


14.	Nominate one Fire Nodal Officer	---	A Fire Nodal Officer shall be nominated either from teaching or non-teaching staff.
15.	Fire fighting training	Not trained	At least 40% of teaching & non teaching staff should be got trained in fire prevention And fire fighting evacuation measures at R.A.Mundkur Fire &Emergency Services Academy, Bannerughatta Road, Bangalore-560 029 or Regional Training center.
16.	<p><u>Fire precautionary measures :-</u></p> <p>A) Explosive and flammable materials should not be stores in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.</p> <p>B) Accumulation of combustibile waste in and the premises should be avoided.</p> <p>C) The exit ways shall be always kept clear without any obstruction.</p> <p>D) Liquefied petroleum gas should not be stores in the building.</p> <p>E) The doors shall not be kept locked / latched during working hours and shall be free from obstruction.</p> <p>F) During the class hours the class room doors shall not be locked from inside to out side.</p> <p>G) As per Honorable Supreme Court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year be conducting Fire Safety drills with co-ordinate Fire Service department.</p>		

Under the above circumstances, Karnataka Fire & Emergency Services Department is issuing Fire Safety Recommendation to "*Kendriya Vidyalaya*" at Sericulture Office building, Near Netaji Stadium, Gauribidanur Taluk, Chikkaballapur District – 561 208. Subject to condition and compliance of the above recommendations as shown in Column-4 of Part-B within 3 months and compliance to the undersigned.

"This Fire Safety Recommendation is valid for Only One Year from the date of issue and it is renewable.

All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.3 of Fire and Life safety will have to be complied with mandatorily.

Yours faithfully,


 Regional Fire Officer
 Bangalore North Range
 Hebbal Fire Station Premises
 Nagawara Ring Road
 Bangalore - 560 045.