



भारत सरकार GOVERNMENT OF INDIA

केन्द्रीय लोक निर्माण विभाग CENTRAL PUBLIC WORKS DEPARTMENT

सहायक अभियंता का कार्यालय (विद्युत) Office of the Assistant Engineer (Electrical)

मंगलूर इलेक्ट्रिकल सब-डिविजन Mangalore Electrical Sub Division

योगक्षेमभवन, एन. आई. टी. के. वेस्ट कैम्पस Yogakshema Building, NITK West Campus

सूरतकल, मंगलूर - 575025 Surathkal, Mangaluru - 575025

Ph: 0824-2476608 e-mail ID: aemesdcpwd@gmail.com



3(4)/ एम. ई. एस. डी/शिविर-मैसूर/2026/56

तारीख: 10/09/2026

TO WHOMSOEVER IT MAY CONCERN

Certified that the work of C/o Kendriya Vidyalaya (A type – 2 sections) and 9 nos staff quarters at Udupi, Karnataka. SH: Building Portion including internal water supply, sanitary installations, drainage and development work, internal electrical installations, fans and fitting etc. at Udupi, Karnataka comprised of Ground + 2 Upper Floors owned/occupied by Kendriya Vidyalaya have complied with the fire prevention and fire safety requirements in accordance with rule of Karnataka State Fire Service Rules, and as per National Building Code 2016. According to KARNATAKA ORDINANCE NO. 01 OF 2023 THE KARNATAKA FIRE FORCE (AMENDMENT) ORDINANCE, 2023 dated 24.03.2023 that came into force with effect from 27.03.2023, it is not mandatory for Kendriya Vidyalaya building to obtain NOC from the Karnataka State Fire and Emergency Services Department as the building height is 11.4 metre which is less than 21 mtr However, the applicable fire and life-safety provisions as stipulated in the National Building Code (NBC) 2016 have been duly considered and the required fire-safety measures have been provided in the building.

Name : ADARSH. U. R.

Signature with seal : 

Assistant Engineer (Electrical)
Mangalore Electrical Sub Division
CPWD, Mangalore

To

✓ The Principal,
Kendriya Vidyalaya School,
Pragathi Nagar, Alevoor village,
Manipal, Udupi, Karnataka-576104.