



**WATER TESTING REPORT**  
**P.H.E. SUB DIVISION LAKHNADON LABORATORY**

s.no	name of location	Recived date	Testing date	chloride (250-1000)mg/l	Alkalinity (200-600)mg/l	Hardness(200-600)mg/l	pH(6.5-8.5)	Fluoride(1.0-1.5)mg/l
1	kendriya vidyalaya/supply water (nagar panchayat)	7/6/2024	7/6/2024	30	125	165	7.5	0.187

  
CHEMIST / LAB ASSISTANT  
P.H.E. SUB DIVISION  
LAKHNADON

  
ASSISTANT ENGINEER  
P.H.E. SUB DIVISION  
LAKHNADON