GOVERNMENT OF ARUNACHAL PRADESH
OFFICE OF THE ASSISTANT ENGINEER::PHE &WS SUB-DIVISION
TEZU::: LOHIT DISTRICT:::::792001

Phone No. 03804-222269
Email ID:- aephetezu@gmail.com

No.TSD/Lab-168 (volII) 2025-2026/55

Dated Tezu the 29th Aug'2026.

To,

The Principal
Kendriya Vidyalaya Tezu

Sub: - **Water Sample Testing Report.**

Sir,

With reference to your letter no. 0421893 -117/KVT/2026-27/157 dated 10/08/2026, quality testing report and safety certificate of the water sample provided by you is furnished herewith for your information.

Enclo:- As stated above.

Yours Sincerely,

Assistant Engineer
PHE & WS Sub Division
Tezu

Assistant Engineer
PHE & WS Sub Division,
Tezu.

Scanned with OKEN Scanner

WATER ANALYSIS REPORT OF KENDRIYA VIDYALAYA TEZU.

S/No	Sample	Date Testing	Parameter								
			Alkalinity Acceptable Limit -500 mg/l	Turbidity Acceptable Limit-5 NTU	pH Acceptable limit- 6.5-8.5	Total Hardness Acceptable Limit-500 mg/l	Total Iron Acceptable limit-1mg/l	Chloride Acceptable Limit-250 Mg/l	Nitrate Acceptable Limit- 1mg/l	Flouride Acceptable Limit-1.5 mg/l	Bacteriological Test
1	Bore well	29.08.2026	65	0.00	7.45	30	0.01	13	0.285	0.01	
2	RO	29.08.2026	80	0.00	7.10	45	0.0	11	0.323	0.00	

Lab Assistant
PHE & WS Sub Division::Tezu

Assistant Engineer
PHE & WS Sub Division::Tezu

Assistant Engineer
PHE & WS
Sub- Division::Tezu

Scanned with OKEN Scanner

SAFE DRINKING WATER CERTICATE

No.TSD/Lab-168 (vol-III) 2025-26/55 Dated the Tezu 29th Aug'2026.

This is certified that the PM Ahri Kendriya Vidyalaya Tezu, Lohit District (A.P) has safe drinking water facilities.

The above valid for a period of 6 months.

Signature with seal :- _____

Assistant Engineer
PHE & WS
Sub- Division Tezu

Name :- Er.Kari Ete

Designation :- Assistant Engineer

Scanned with OKEN Scanner