



OIL AND NATURAL GAS CORPORATION LIMITED

Fire Services, Western Onshore Basin

Makarpura Road, Vadodara-390009

Phone Nos. 0265-2603606/ 2603612/2603501

No. BDA/FS/FS COMPLIANCE-KV/2025

Date: 26.06.2025

Compliance of Fire-Safety measures at Kendriya Vidyalaya No.4, ONGC Vadodara

Kendriya Vidyalaya No.4, ONGC Vadodara which is located at ONGC Campus, Makarpura Road, ONGC, Vadodara having Ground floor only. It has been provided with the required fire prevention and protection facilities like fire extinguishers, fire alarm systems and smoke detectors at designated places of School. All the equipment's are in working condition and well maintained. Fire risks involved is of very low category and evacuation can be done easily in case of any emergency as all the exits are at ground floor & free from any obstructions.

This school is protected by following firefighting equipment's to cater any fire emergency:

Fire Extinguishers:


▪ 4.5 Kg Capacity CO2 Fire Extinguisher	05 nos.
▪ 2.0 Kg Capacity CO2 Fire Extinguisher	02 nos.
▪ 09 Kg Capacity DCP (ABC Type) Fire Extinguishers	09 nos.
▪ 2.0 Kg Capacity DCP (ABC Type) Fire Extinguishers	03 nos.
▪ Fire Buckets (4 nos.) with stand	01 nos.

Fire Alarm System

▪ MCP	07 nos.
▪ Hooters	07 nos.
▪ Smoke Detectors	19 nos.

All above fire equipment's are installed, tested, maintained in working condition and same are being checked on quarterly basis by the Fire Services, ONGC. The compliance is being done as per the guidelines of National building Code of India (NBC) & Gujrat State Fire Services.

This letter is being issued as per the requirement of KV, No.4, ONGC Vadodara which is valid for one year from the date of issuance.


(Sandip B Rangari)
DGM - I/c Fire Services
ONGC, Vadodara.

Copy to:

1. The Principal, Kendriya Vidyalaya No.4, ONGC Campus, Vadodara.
2. Office of ED-Basin Manager, WON Basin, Vadodara.