

BUILDING SAFETY CERTIFICATE

No. 23(141)/KaCD/2026/ 546

Dated: 20.08.2026

Certified that the existing building **Kendriya Vidyalaya, No.1, CPCRI, Kasaragod School building** (name of the building or premises) at **Kasaragod Dist., Kerala** (address) comprised of **Ground floor** basement(s) and **First floor** (upper floors) owned/occupied by **Kendriya Vidyalaya, No.1, CPCRI, Kasaragod** (name of the Institution) have complied with the Building safety requirements in accordance with National Building Code Rules, and verified by the officers concerned of **CPWD** (Name of Department/ Govt.) on **06.08.2026** (date of inspection) in the presence of **Shri. K. P. Sudhakaran, Principal, Kendriya Vidyalaya, No.1, CPCRI, Kasaragod** (name and addresses of the Manager/Secretary or his representative) and that the buildings/premises upto classes **XII** (XI XII) are fit for occupancy with effect from **06.08.2026** for a period of **One Year** in accordance with rule and subject to compliance of the specific conditions as appended **with the exception of three classrooms in the old building which has major structural cracks and therefore, the said classrooms are not considered safe for use. It is also necessary to provide proper barricading around the damaged wall/affected portion to prevent students from approaching the unsafe area.**

1. Proper barricading shall be provided around the damaged wall/affected portion to prevent students from entering or approaching the unsafe area.
2. The restricted portion shall not be used until necessary structural remedial measures are carried out and the portion is certified safe for occupation.
3. Upkeep and maintenance including clearing of jungle and grass, cleaning of blockages from the inlet mouths of rain water pipes, desilting of drainages, etc.
4. Internal and external paintings of walls to be done at required intervals.
5. Branches of the trees standing adjacent to the building has to be cut off.
6. Any structural cracks developed shall be immediately reported and to be attended.

This certificate does not cover the Electrical installation including fire protection and shall be valid for one year from the date of inspection.

Issued on 20.08.2026 at 02.00 PM by



Signature with seal:

Name: Sajeev. S. N.

Designation: Executive Engineer – Kannur.

Name & Address of Department/Office: CPWD, Kannur.


कार्यपालक अभियंता
Executive Engineer
कण्णूर केन्द्रीय मंडल
Kannur Central Division
के.लो.नि.वि. कण्णूर-१
CPWD, KANNUR-1



കേന്ദ്രീയ വിദ്യാലയ നം.1. സി പി സി ആർ ഐ കാസർഗോഡ് - 671 124
केन्द्रीय विद्यालय नं.1.के. रो. फ. आ.सं, पो – कुडलु, कासरगोड-671124
KENDRIYA VIDYALAYA NO. 1. CPCRI, P.O.KUDLU, KASARAGOD – 671 124
(KERALA)(KVS – An autonomous body under Ministry of Education – Govt. of India)
<https://no1kasragod.kvs.ac.in> Email-kv1cpcr@gmail.com Tele:04994 232787

F.5-34 /KV-CPCRI/2026-27/

Date: 21-08-2026


SELF - DECLARATION

I hereby declare that the estimate for the required repair work has already been obtained. The work will be taken up by CPCRI at the earliest, on receipt of the necessary approval from ICAR, and will be completed on priority.

Meanwhile, adequate precautionary measures are being taken to ensure the safety of the students and to avoid any inconvenience. The concerned classrooms will be used only after ensuring that they are safe for occupation.

Date: 21-08-2026

Place: KASARAGOD.


Signature: 21/08/26.

Name & Designation: K.P. Sudhakaran
Principal
केन्द्रीय विद्यालय नं.1 के.रो.फ.अ.सं. PRINCIPAL
KENDRIYA VIDYALAYA, No.1, CPCRI
कासरगोड / KASARAGOD-671 124